CHAPTER XXV

STORMWATER MANAGEMENT

Part 1

General Provisions

Section 101.	Short Title
Section 102.	Statement of Findings
Section 103.	Purpose
Section 104.	Statutory Authority
Section 105.	Applicability/Regulated Activities
Section 106.	Repealer
Section 107.	Severability
Section 108.	Compatibility with Other Ordinance Requirements

Part 2

Definitions

Section 201.	Interpretation
Section 202.	Definitions

Part 3

Stormwater Management

Section 301.	General Requirements
Section 302.	Requirements by Other Government Entities
Section 303.	Erosion and Sediment Pollution Control During Regulated Earth
	Disturbance Activities
Section 304.	Nonstructural Project Design (Sequencing to Minimize Stormwater
	Impacts)
Section 305.	Ground Water Recharge (Infiltration/Recharge/Bioretention)
Section 306.	Water Quality Requirements
Section 307.	Streambank Erosion Requirements
Section 308.	Stormwater Management Districts
Section 309.	Calculation Methodology
Section 310	Other Requirements

Drainage Plan Requirements

Section 402. Exemptions Section 403. Drainage Plan Contents Section 404. Plan Submission Section 405. Drainage Plan Review Section 406. Modification of Plans Section 407. Resubmission of Disapproved Drainage Plans	Section 401.	General Requirements
Section 404. Plan Submission Section 405. Drainage Plan Review Section 406. Modification of Plans	Section 402.	Exemptions
Section 405. Drainage Plan Review Section 406. Modification of Plans	Section 403.	Drainage Plan Contents
Section 406. Modification of Plans	Section 404.	Plan Submission
	Section 405.	Drainage Plan Review
Section 407. Resubmission of Disapproved Drainage Plans	Section 406.	Modification of Plans
	Section 407.	Resubmission of Disapproved Drainage Plans

Part 5

Inspections

Section 501. Schedule of Inspections

Part 6

Fees and Expenses

Section 601.	Township Drainage Plan Review and Inspection Fees
Section 602.	Expenses Covered by Fees

Part 7

Maintenance Responsibilities

Section 701.	Performance Guarantee	
Section 702.	Adherence to Approved Stormwater Control and BMP Operations	
	and Maintenance Plan	
Section 703.	Operations and Maintenance Agreement for Privately Owned	
	Stormwater Controls and BMPs	
Section 704.	Stormwater Management Easements	
Section 705.	Recording of Approved Stormwater Control and BMP Operations and	
	Maintenance Plan and Related Agreements	
Section 706.	Township Stormwater Control and BMP Operation and Maintenance	
	Fund	

Prohibitions

Section 801.	Prohibited	Discharges and	Connections

Section 802. Roof Drains

Section 803. Alteration of SWM BMPs

Part 9

Enforcement and Penalties

Section 901.	Right-of-Entry
Section 902.	Public Nuisance
Section 903.	General Enforcement
Section 904.	Suspension and Revocation of Permits and Approvals
Section 905.	Penalties
Section 906.	Notification
Section 907.	Enforcement

Part 10

Appendices

Section 1001. Appendix A - Stormwater Controls and Best Management Practices
Operations and Maintenance Agreement

Section 1002. Appendix B - Stormwater Management Design Criteria

Section 1003. Appendix C – Drainage Plan Application

Section 1004. Appendix D - Stormwater Management District Watershed Map

Section 1005. Appendix E – Low Impact Development Practices

Section 1006. Appendix F - West Nile Virus Guide

Section 1007. Appendix G - References

General Provisions

Section 101. Short Title. This Chapter shall be known and may be cited as the Township of Spring Stormwater Management Ordinance"). (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 102.</u> Statement of Findings. The Board of Supervisors of the Township of Spring finds that:

- (A) Inadequate management of accelerated stormwater runoff resulting from development throughout a watershed increases flood flows and velocities, contributes to erosion and sedimentation, overtaxes the carrying capacity of existing streams and storm sewers, greatly increases the cost of public facilities to convey and manage stormwater, undermines floodplain management and flood reduction efforts in upstream and downstream communities, reduces groundwater recharge, and threatens public health and safety.
- (B) Inadequate planning and management of stormwater runoff resulting from land development and redevelopment throughout a watershed can also harm surface water resources by changing the natural hydrologic patterns, accelerating stream flows (which increase scour and erosion of stream-beds and stream-banks thereby elevating sedimentation), destroying aquatic habitat and elevating aquatic pollutant concentrations and loadings such as sediments, nutrients, heavy metals and pathogens. Groundwater resources are also impacted through loss of recharge.
- (C) A comprehensive program of stormwater management (SWM), including minimization of impacts of development, redevelopment and activities causing accelerated erosion, is fundamental to the public health, safety, welfare, and the protection of the people of the Township and all the people of the Commonwealth, their resources, and the environment.
- (D) Inadequate management of accelerated stormwater runoff resulting from development throughout a watershed poses a threat to surface and groundwater quality.
- (E) Stormwater can be an important water resource by providing groundwater recharge for water supplies and base flow of streams, which also protects and maintains surface water quality.

- (F) Impacts from stormwater runoff can be minimized by using project designs that maintain the natural hydrologic regime, and sustain high water quality, groundwater recharge, stream baseflow and aquatic ecosystems. The most cost effective and environmentally advantageous way to manage storm water runoff is through nonstructural project design, minimizing impervious surfaces and sprawl, avoiding sensitive areas (i.e. stream buffers, floodplains, steep slopes), and designing to topography and soils to maintain the natural hydrologic regime.
- (G) Public education on the control of pollution from stormwater is an essential component in successfully addressing stormwater.
- (H) Federal and state regulations require certain municipalities to implement a program of stormwater controls. These municipalities are required to obtain a permit for stormwater discharges from their separate storm sewer systems under the National Pollutant Discharge Elimination System (NPDES).
- (I) Non-stormwater discharges to municipal separate storm sewer systems can contribute to pollution of waters of the Commonwealth by the Township.

<u>Section 103. Purpose.</u> The purpose of this Chapter is to promote the public health, safety, and welfare within the Township of Spring by maintaining the natural hydrologic regime by minimizing the impacts described in <u>Section 102</u> of this Chapter through provisions designed to:

- (A) Promote alternative project designs and layout that minimizes impacts to surface and ground water.
 - (B) Promote nonstructural Best Management Practices (BMPs).
 - (C) Minimize increases in stormwater volume.
 - (D) Minimize impervious surfaces.
- (E) Manage accelerated runoff and erosion and sedimentation problems at their source by regulating activities that cause these problems.
- (F) Provide review procedures and performance standards for stormwater planning and management.

- (G) Utilize and preserve the existing natural drainage systems.
- (H) Manage stormwater impacts close to the runoff source, which requires a minimum of structures and relies on natural processes.
- (I) Focus on infiltration of stormwater, to maintain groundwater recharge, to prevent degradation of surface and groundwater quality and to otherwise protect water resources.
- (J) Maintain existing base flows and quality of streams and watercourses, where possible.
- (K) Meet legal water quality requirements under state law, including regulations at 25 Pa. Code Chapter 93.4a to protect and maintain "existing uses" and maintain the level of water quality to support those uses in all streams, and to protect and maintain water quality in "special protection" streams.
- (L) Address the quality and quantity of stormwater discharges from the development site.
- (M) Provide a mechanism to identify controls necessary to meet the NPDES permit requirements.
- (N) Implement an illegal discharge detection and elimination program to address non-stormwater discharges into the Township's separate storm sewer system.
 - (O) Preserve and restore the flood-carrying capacity of streams.
 - (P) Prevent scour and erosion of streambanks and streambeds.
- (Q) Provide performance standards and design criteria for watershed-wide stormwater management and planning.
- (R) Provide proper operation and maintenance of all permanent stormwater management facilities and BMPs that are implemented in the Township.
- (S) NPDES Requirements. Federal regulations approved October 1999 require operators of small municipal separate storm sewer systems (MS4s) to obtain NPDES Phase II permits from PaDEP by March 2003. (NPDES II is an acronym for the National Pollutant Discharge Elimination System Phase II Stormwater Permitting Regulations.) This program affects all municipalities in "urbanized"

areas" of the state. This definition applies to all Schuylkill River watershed municipalities identified in Table III-1 of the Schuylkill River Stormwater Management Plan Volume II as NPDES Phase II municipalities. Therefore, these identified municipalities will be subject to the NPDES Phase II requirements mandated by the Federal Clean Water Act as administered by PaDEP. For more information on NPDES II requirements, contact the PaDEP Regional Office.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 104. Statutory Authority.

- (A) Primary Authority. The Township is empowered to regulate these activities by the authority of the Act of October 4, 1978, P.L. 864 (Act 167), 32 P.S. Section 680.1, et seq., as amended, the "Storm Water Management Act" and the Pennsylvania Second Class Township Code, 53 P.S. Section 65101, et seq., as amended.
- (B) Secondary Authority. The Township also is empowered to regulate land use activities that affect runoff by the authority of the Act of July 31, 1968, P.L. 805, No. 247, The Pennsylvania Municipalities Planning Code, as amended.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 105. Applicability/Regulated Activities. All Regulated Activities and all activities that may affect stormwater runoff, including Land Development and Earth Disturbance Activity, are subject to regulation by this Chapter. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 106.</u> Repealer. Any ordinance or ordinance provision of this Township inconsistent with any of the provisions of this Chapter is hereby repealed to the extent of the inconsistency only. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 107. Severability.</u> Should any section or provision of this Chapter be declared invalid by a court of competent jurisdiction, such decision shall not affect the validity of any of the remaining provisions of this Chapter. (Ordinance No. 355, March 24, 2008, Section 1)

Section 108. Compatibility With Other Ordinance Requirements. Approvals issued and actions taken under this Chapter do not relieve the Applicant of the responsibility to secure required permits or approvals for activities by any other code, law, regulation or ordinance. (Ordinance No. 355, March 24, 2008, Section 1)

Definitions

<u>Section 201. Interpretation.</u> For the purposes of this Chapter, certain terms and words used herein shall be interpreted as follows:

- (A) Words used in the present tense include the future tense; the singular number includes the plural, and the plural number includes the singular; words of masculine gender include feminine gender; and words of feminine gender include masculine gender.
- (B) The word "includes" or "including" shall not limit the term to the specific example, but is intended to extend its meaning to all other instances of like kind and character.
- (C) The word "person" includes an individual, firm, association, organization, partnership, trust, company, corporation, unit of government, or any other similar entity.
- (D) The words "shall" and "must" are mandatory; the words "may" and "should" are permissive.
- (E) The words "used or occupied" include the words "intended, designed, maintained, or arranged to be used, occupied or maintained."

(Ordinance No. 355, March 24, 2008, Section 1)

Section 202. Definitions.

Accelerated Erosion - The removal of the surface of the land through the combined action of man's activity and the natural processes of a rate greater than would occur because of the natural process alone.

Agricultural Activities - The work of producing crops and raising livestock including tillage, plowing, disking, harrowing, pasturing and installation of conservation measures. For purposes of regulation by this Chapter construction of new buildings or impervious area is not considered an agricultural activity.

Alteration - As applied to land, a change in topography as a result of the moving of soil and rock from one location or position to another; also the changing of surface conditions by causing the surface to be more or less impervious; land disturbance.

As-built drawings - Those maintained by the Contractor as he constructs the project and upon which he documents the actual locations of the building components and changes to the original contract documents. An accurately drafted version of same are turned over to the Township at the completion of the project as the "record as-built drawings".

Applicant - A person who has filed an application for approval to engage in any Regulated Activities as defined in <u>Section 105</u> of this Chapter.

Bankfull – The channel at the top-of-bank or point where water begins to overflow onto a floodplain.

Base Flow - Portion of stream discharge derived from groundwater; the sustained discharge that does not result from direct runoff or from water diversions, reservoir releases, piped discharges, or other human activities.

Bioretention - A stormwater retention area which utilizes woody and herbaceous plants and soils to remove pollutants before infiltration occurs.

BMP (Best Management Practice) – Activities, facilities, designs, measures or procedures used to manage stormwater impacts from land development, to protect and maintain water quality and groundwater recharge and to otherwise meet the purposes of this Chapter, including but not limited to, structural and non-structural stormwater management practices and operation and maintenance procedures. See also Non-structured Best Management Practice (BMP).

Board of Supervisors - The Board of Supervisors of the Township of Spring.

Buffer - The area of land immediately adjacent to any stream, measured perpendicular to and horizontally from the top-of-bank on both sides of a stream. (See Top of Bank)

Channel - A drainage element in which stormwater flows with an open surface. Open channels include, but shall not be limited to, natural and man-made drainage ways, swales, streams, ditches, canals, and pipes flowing partly full.

Channel Erosion - The widening, deepening, and headward cutting of small channels and waterways, caused by stormwater runoff or bankfull flows.

Chapter 102 - Chapter 102 of the regulations of PaDEP, 25 Pa. Code Sect. 102.1 et seq.

Chapter 105 - Chapter 105 of the regulations of PaDEP, 25 Pa. Code Sect. 105.1 et seq.

Chapter 106 - Chapter 106 of the regulations of PaDEP, 25 Pa. Code Sect. 106.1 et seq.

Cistern - An underground reservoir or tank for storing rainwater.

Conservation District - The Berks County Conservation District.

Culvert - A structure with appurtenant works, which carries water under or through an embankment or fill.

Dam - An artificial barrier, together with its appurtenant works, constructed for the purpose of impounding or storing water or another fluid or semifluid, or a refuse bank, fill or structure for highway, railroad or other purposes which does or may impound water or another fluid or semifluid.

Department - The Pennsylvania Department of Environmental Protection (PaDEP).

Designee - The agent of the Berks County Planning Commission, Berks County Conservation District and/or agent of the Board of Supervisors involved with the administration, review or enforcement of any provisions of this Chapter by contract or memorandum of understanding.

Design Professional (Qualified) – Any person licensed by the Pennsylvania Department of State or otherwise qualified by law to perform the work required by the Chapter.

Design Storm - The magnitude and temporal distribution of precipitation from a storm event measured in probability of occurrence (e.g., a 5-year storm) and duration (e.g., 24-hours), used in the design and evaluation of stormwater management systems.

Designated Watershed (ACT 167) – A Watershed which is listed under the Pennsylvania Department of Environmental Protection's "Index of Designated Watersheds (Stormwater Management)" pursuant to the Stormwater Management Act P.L. 864, No. 167, October 4, 1978, and published in the Pennsylvania Bulletin on May 31, 1980 and August 9, 1980, as amended on November 19, 1991, April 21, 1992, June 21, 1994, April 16, 1996, April 15, 1997 and December 16, 1997).

Detention Basin - An impoundment designed to collect and retard stormwater runoff by temporarily storing the runoff and releasing it at a predetermined rate. Detention basins are designed to drain completely shortly after any given rainfall event and are dry until the next rainfall event.

Developer – A person that seeks to undertake any Regulated Activities at a project site in the Township.

Development – Any human-induced change to improved or unimproved real estate, whether public or private, including but not limited to land development, construction, installation, or expansion of a building or other structure, land division, street construction, drilling, and site alteration such as embankments, dredging, grubbing, grading, paving, parking or storage facilities, excavation, filling, stockpiling, or clearing. As used in this Chapter, development encompasses both new development and redevelopment.

Development Site - The specific tract of land where any Regulated Activities in the Township are planned, conducted or maintained.

Diffused Drainage Discharge - Drainage discharge not confined to a single point location or channel, such as sheet flow or shallow concentrated flow.

Discharge – 1. (verb) To release water from a project, site, aquifer, drainage basin or other point of interest 2. (noun) The rate and volume of flow of water such as in a stream, generally expressed in cubic feet per second (volume per unit of time). See also Peak Discharge.

Discharge Point - The point of discharge for a stormwater facility.

Disturbed Areas - Unstabilized land area where an earth disturbance activity is occurring or has occurred.

Ditch - An artificial waterway for irrigation or stormwater conveyance.

Downslope Property Line - That portion of the property line of the lot, tract, or parcels of land being developed located such that overland or pipe flow from the site would be directed towards it.

Drainage Conveyance Facility - A Stormwater Management Facility designed to transmit stormwater runoff and shall include channels, swales, pipes, conduits, culverts, storm sewers, etc.

Drainage Easement - A right granted by a landowner to a grantee, allowing

the use of private land for stormwater management purposes.

Drainage Permit - A permit issued by the Township after the drainage plan has been approved.

Drainage Plan - The plan prepared by the Applicant or his representative indicating how stormwater runoff will be managed at the particular site of interest according to this Chapter.

Earth Disturbance Activity – A construction or other human activity which disturbs the surface of land, including, but not limited to, clearing and grubbing, grading, excavations, embankments, land development, agricultural plowing or tilling, timber harvesting activities, road maintenance activities, mineral extraction, and the moving, depositing, stockpiling, or storing of soil, rock or earth materials.

Emergency Spillway – A conveyance area that is used to pass peak discharge greater than the maximum design storm controlled by the stormwater facility.

Encroachment – A structure or activity that changes, expands or diminishes the course, current or cross section of a watercourse, floodway or body of water.

Ephemeral Stream - A transient stream, one that flows for a relatively short time.

Erosion - The process by which the surface of the land, including channels, is worn away by water, wind, or chemical action.

Erosion and Sediment Pollution Control Plan - A plan for a project site which identifies BMPs to minimize accelerated erosion and sedimentation.

Exceptional Value Waters - Surface waters of high quality which satisfy Pennsylvania Code Title 25 Environmental Protection, Chapter 93, Water Quality Standards, § 93.4b(b) (relating to anti-degradation).

Existing Conditions - The initial condition of a project site prior to the proposed alteration. If the initial condition of the site is undeveloped land, the land use shall be considered as "meadow" unless the natural land cover is proven to generate lower curve numbers or Rational "C" value, such as forested lands.

Flood - A temporary condition of partial or complete inundation of land areas from the overflow of streams, rivers, and other waters of this Commonwealth.

Floodplain - Any land area susceptible to inundation by water from any

natural source or delineated by applicable Department of Housing and Urban Development, Federal Insurance Administration Flood Hazard Boundary - Mapped as being a special flood hazard area.

Floodway - The channel of the watercourse and those portions of the adjoining floodplains, which are reasonably required to carry and discharge the 100-year frequency flood. Unless otherwise specified, the boundary of the floodway is as indicated on maps and flood insurance studies provided by FEMA. In an area where no FEMA maps or studies have defined the boundary of the 100-year frequency floodway, it is assumed - absent evidence to the contrary - that the floodway extends from the stream to 50 feet from the top-of-bank.

Fluvial Geomorphology - The study of landforms associated with river channels and the processes that form them.

Forest Management/Timber Operations - Planning and activities necessary for the management of forest land with no change of land use proposed. These include timber inventory and preparation of forest management plans, silvicultural treatment, cutting budgets, logging road design and construction, timber harvesting and reforestation.

Freeboard - A vertical distance between the elevation of the design highwater and the top of a dam, levee, tank, basin, swale, or diversion berm. The space is required as a safety margin in a pond or basin.

Grade - A slope, usually of a road, channel or natural ground specified in percent and shown on plans as specified herein. (To) Grade - to finish the surface of a roadbed, top of embankment or bottom of excavation.

Grassed Waterway - A natural or constructed waterway, usually broad and shallow, covered with erosion-resistant grasses, used to convey surface water.

Groundwater - Water beneath the earth's surface, often between saturated soil and rock that supplies wells and springs.

Groundwater Recharge - Replenishment of existing natural underground water supplies without degrading groundwater quality.

HEC-HMS - The U.S. Army Corps of Engineers, Hydrologic Engineering Center (HEC) - Hydrologic Modeling System (HMS).

High Quality Waters – Surface waters having quality which exceeds levels necessary to support propagation of fish, shellfish, and wildlife and recreation in

and on the water by satisfying Pennsylvania Code Title 25 Environmental Protection, Chapter 93 Water Quality Standards, § 93.4b(a).

Hotspots - Areas where land use or activities generate highly contaminated runoff, with concentrations of pollutants in excess of those typically found in stormwater.

Hydrograph – A graph of discharge versus time for a selected point in the drainage system.

Hydrologic Regime (natural) – The hydrologic cycle or balance that sustains quality and quantity of stormwater, baseflow, storage, and groundwater supplies under natural conditions.

Hydrologic Soil Group, - A classification of soils by the Natural Resources Conservation Service, formerly the Soil Conservation Service, into four runoff potential groups. The groups range from A soils, which are very permeable and produce little runoff, to D soils, which are not very permeable and produce much more runoff.

Impervious Surface - A surface that prevents the infiltration of water into the ground. Impervious surface includes, but is not limited to, any roof, parking or driveway areas, and any new streets and sidewalks. Any surface areas designed to be gravel or crushed stone shall be assumed to be impervious surfaces.

Impoundment - A retention or detention basin designed to retain stormwater runoff and release it at a controlled rate.

Infill – Development that occurs on smaller parcels that remain undeveloped but are within or very close proximity to urban areas. The development relies on existing infrastructure and does not require an extension of water, sewer or other public utilities.

Infiltration – Movement of surface water into the soil, where it is absorbed by plant roots, evaporated into the atmosphere, or percolates downward to recharge groundwater.

Infiltration Structures - A structure designed to direct runoff into the underground water (e.g., french drains, seepage pits, seepage trench).

Inlet - The upstream end of any structure through which water may flow.

Intermittent Stream - A stream that flows only part of the time. Flow generally occurs for several weeks or months in response to seasonal precipitation, due to groundwater discharge.

Land Development - Any of the following activities:

- (1) The improvement of one lot or two or more contiguous lots, tracts, or parcels of land for any purpose involving:
 - (a) A group of two or more residential or nonresidential buildings, whether proposed initially or cumulatively, or a single nonresidential building on a lot or lots regardless of the number of occupants or tenure, or
 - (b) The division or allocation of land or space, whether initially or cumulatively, between or among two or more existing or prospective occupants by means of, or for the purpose of streets, common areas, leaseholds, condominiums, building groups, or other features;
 - (2) A subdivision of land;
- (3) Development in accordance with Section 503(1.1) of the PA Municipalities Planning Code.

Limiting zone – A soil horizon or condition in the soil profile or underlying strata which includes one of the following:

- (1) A seasonal high water table, whether perched or regional, determined by direct observation of the water table or indicated by soil mottling.
- (2) A rock with open joints, fracture or solution channels, or masses of loose rock fragments, including gravel, with insufficient fine soil to fill the voids between the fragments.
- (3) A rock formation, other stratum or soil condition which is so slowly permeable that it effectively limits downward passage of water.

Lineament - A fracture on the order of 10's of kilometers long, usually extending to the basement below sedimentary rock.

Lot - A designated parcel, tract or area of land established by a plat or

otherwise as permitted by law and to be used, developed or built upon as a unit.

Main Stem (Main Channel) - Any stream segment or other runoff conveyance facility used as a reach in the hydrologic model for any watershed covered in this Ordinance.

Manning Equation (Manning formula) - A method for calculation of velocity of flow (e.g., feet per second) and flow rate (e.g., cubic feet per second) in open channels based upon channel shape, roughness, depth of flow and slope. "Open channels" may include closed conduits so long as the flow is not under pressure.

Natural Condition - Existing conditions

Natural Hydrologic Regime (see hydrologic regime)

Natural Recharge Area - Undisturbed surface area or depression where stormwater collects, and a portion of which infiltrates and replenishes the underground and groundwater.

Nonpoint Source Pollution - Pollution that enters a water body from diffuse origins in the watershed and does not result from discernible, confined, or discrete conveyances.

Non-stormwater Discharges - Water flowing in stormwater collection facilities, such as pipes or swales, which is not the result of a rainfall event or snowmelt.

Nonstructural Best Management Practice (BMPs) – Methods of controlling stormwater runoff quantity and quality, such as innovative site planning, impervious area and grading reduction, protection of natural depression areas, temporary ponding on site and other techniques.

NPDES - National Pollutant Discharge Elimination System, the federal government's system for issuance of permits under the Clean Water Act, which is delegated to PaDEP in Pennsylvania.

NRCS - Natural Resource Conservation Service (previously SCS).

Open Channel – A drainage element in which stormwater flows with an open surface. Open channels include, but shall not be limited to natural and man-made drainageways, swales, streams, ditches, canals and pipes flowing partially full.

Outfall - "Point source" as described in 40 CFR § 122.2 at the point where the Township's storm sewer system discharges to surface waters of the Commonwealth.

Outlet - Points of water disposal to a stream, river, lake, tidewater or artificial drain.

Parent Tract - The parcel of land from which a land development or subdivision originates, determined from the date of the Township's adoption of this Chapter.

Parking Lot Storage - Involves the use of parking areas as temporary impoundments with controlled release rates during rainstorms.

Peak Discharge - The maximum rate of stormwater runoff from a specific storm event.

Penn State Runoff Model - The computer-based hydrologic model developed at the Pennsylvania State University.

Pipe - A culvert, closed conduit, or similar structure (including appurtenances) that conveys stormwater.

Planning Commission - The planning commission of the Township of Spring.

Point Source - any discernible, confined and discrete conveyance, including, but not limited to, any pipe, ditch, channel, tunnel, or conduit from which stormwater is or may be discharged, as defined in State regulations at 25 Pa. Code § 92.1.

Post Construction - Period after construction where disturbed areas are stabilized, stormwater controls are in place and functioning and all proposed improvements in the approved land development plan are completed.

Pretreatment – Techniques employed in stormwater BMPs to provide storage or filtering to trap coarse materials and other pollutants before they enter the system, but not necessarily meet the water quality volume requirements of Section 306.

Project Site - The specific area of land where any Regulated Earth Disturbance activities in the Township are planned, conducted or maintained.

Rain Garden - A BMP overlain with appropriate mulch and suitable vegetation designed, constructed, and maintained for the purpose of providing

infiltration or recharge of stormwater into the soil and/or underground aquifer.

Rational Formula - A rainfall-runoff relation used to estimate peak flow.

Recharge - The replenishment of groundwater through the infiltration of rainfall, other surface waters, or land application of water or treated wastewater.

Reconstruction - Demolition of, and subsequent rebuilding of impervious surface.

Record As-built Drawings - Original documents revised to suit the as-built conditions and subsequently provided by the applicant to the Township.

Redevelopment – The demolition, construction, reconstruction, alteration, or improvement exceeding 2,000 square feet of land disturbance performed on sites where existing land use is commercial, industrial, institutional, or multifamily residential. Maintenance activities such as top-layer grinding and re-paving are not considered to be redevelopment. Interior remodeling projects and tenant improvements are also not considered to be redevelopment. Utility trenches in streets are not considered redevelopment unless more than 50% of the street width is removed and re-paved.

Regulated Activities - Any actions or proposed actions that involve the alteration or development of land in a manner that may affect stormwater runoff.

Regulated Earth Disturbance Activity - Activity involving Earth Disturbance subject to regulation under 25 PA Code Chapters 92, Chapter 102, or the Clean Streams Law.

Release Rate - The percentage of existing conditions peak rate of runoff from a site or subarea to which the proposed conditions peak rate of runoff must be reduced to protect downstream areas.

Repaving – Replacement of the impervious surface that does not involve reconstruction of an existing paved (impervious) surface.

Replacement Paving – Reconstruction of and full replacement of an existing paved (impervious) surface.

Retention Basin - A structure in which stormwater is stored and not released during the storm event. Retention basins do not typically have an outlet to other down stream conveyance features such as channels, storm sewer, or other surface waters. Generally, these features empty via recharge and must infiltrate stored

water in no more than 4 days. These features may have an emergency spillway or other overflow device for large events.

Return Period - The average interval, in years, within which a storm event of a given magnitude can be expected to recur. For example, the 25-year return period rainfall would be expected to recur on the average of once every twenty-five years.

Riser - A vertical pipe extending from the bottom of a pond that is used to control the discharge rate from the pond for a specified design storm.

Road Maintenance - Earth disturbance activities within the existing road cross-section, such as grading and repairing existing unpaved road surfaces, cutting road banks, cleaning or clearing drainage ditches and other similar activities.

Roof Drains - A drainage conduit or pipe that collects water runoff from a roof and leads it away from the structure.

Rooftop Detention - Temporary ponding and gradual release of stormwater falling directly onto flat roof surfaces by incorporating controlled-flow roof drains into building designs.

Runoff - Any part of precipitation that flows over the land surface.

SALDO - The Township Subdivision and Land Development Ordinance.

Sediment Basin - A barrier, dam, retention or detention basin located and designed to retain rock, sand, gravel, silt, or other material transported by water during construction.

Sediment Pollution - The placement, discharge or any other introduction of sediment into the waters of the Commonwealth.

Sedimentation - The process by which mineral or organic matter is accumulated or deposited by the movement of water or air.

Seepage Pit/Seepage Trench - An underground BMP structure designed, constructed, and maintained for the purpose of providing infiltration or recharge of stormwater into the soil and/or groundwater aquifer.

Separate Storm Sewer System - A conveyance or system of conveyances (including roads with drainage systems, municipal streets, catch basins, curbs, gutters, ditches, man-made channels or storm drains) primarily used for collecting and conveying stormwater runoff.

Shallow Concentrated Flow - Stormwater runoff flowing in shallow, defined ruts prior to entering a defined channel or waterway.

Sheet Flow – A flow process associated with broad, shallow water movement on sloping ground surfaces that is not channelized or concentrated.

Soil-Cover Complex Method - A method of runoff computation developed by the NRCS that is based on relating soil type and land use/cover to a runoff parameter called Curve Number (CN).

Source Water Protection Areas (SWPA) - The zone through which contaminants, if present, are likely to migrate and reach a drinking water well or surface water intake.

Special Geologic Features - Carbonate bedrock features, including but not limited to closed depressions, existing sinkholes, fracture traces, lineaments, joints, faults, intermittent lakes, ephemeral streams, caves and pinnacles, which may exist and must be identified on a site when stormwater management BMPs are being considered.

Special Protection Subwatersheds - Watersheds for which the receiving waters are exceptional value (EV) or high quality (HQ) waters.

Spillway - A conveyance that is used to pass the peak discharge of the maximum design storm controlled by the stormwater facility.

State Water Quality Requirements - The regulatory requirements to protect, maintain, reclaim, and restore water quality under Pennsylvania Code Title 25 and the Clean Streams Law.

Storage Indication Method - A reservoir routing procedure based on solution of the continuity equation (inflow minus outflow equals the change in storage) with outflow defined as a function of storage volume and depth.

Storm Frequency - The number of times that a given storm "event" occurs or is exceeded on the average in a stated period of years. See "Return Period".

Storm Sewer - A system of pipes and/or open channels that conveys intercepted runoff and stormwater from other sources, but excludes domestic sewage and industrial wastes.

Stormwater - The surface runoff generated by precipitation reaching the ground surface.

Stormwater Management District - Those subareas in which some type of detention is required to meet the plan requirements and the goals of Act 167.

Stormwater Management Facility - Any structure, natural or man-made, that, due to its condition, design, or construction, conveys, stores, or otherwise affects stormwater runoff quality, rate or quantity. Typical stormwater management facilities include, but are not limited to, detention and retention basins, open channels, storm sewers, pipes, and infiltration structures.

Stormwater Management Plan - The plan for managing those land use activities that will influence stormwater runoff quality and quantity and that would impact the tributaries within any Watershed for which Berks County has adopted a Stormwater Management Plan as required by the Act of October 4, 1978, P.L. 864, (Act 167).

Stream - A natural watercourse.

Stream Buffer – The land area adjacent to each side of a stream, essential to maintaining water quality. (See Buffer)

Stream Enclosure - A bridge, culvert or other structure in excess of 100 feet in length upstream to downstream which encloses a regulated water of this Commonwealth.

Subarea (Subwatershed)- The smallest drainage unit of a watershed for which stormwater management criteria have been established in the Stormwater Management Plan.

Subdivision - The division or redivision of a lot, tract, or parcel of land by any means into two or more lots, tracts, parcels or other divisions of land including changes in existing lot lines for the purpose, whether immediate or future, of lease, partition by the court for distribution to heirs or devisees, transfer of ownership, or building or lot development: Provided, however, that the subdivision by lease of land for agricultural purposes into parcels of more than ten acres, not involving any new street or easement of access or any residential dwelling, shall be exempted.

Surface Waters of the Commonwealth - Any and all rivers, streams, creeks, rivulets, ditches, watercourses, storm sewers, lakes, dammed water, wetlands, ponds, springs, and all other bodies or channels of conveyance of surface, or parts thereof, whether natural or artificial, within or on the boundaries of this Commonwealth.

Swale - A low lying stretch of land which gathers or carries surface water runoff.

Timber Operations - See Forest Management.

Time-of-Concentration (Tc) - The time for surface runoff to travel from the hydraulically most distant point of the watershed to a point of interest within the watershed. This time is the combined total of overland flow time and flow time in pipes or channels, if any.

Top-of-Bank – Highest point of elevation in a stream channel cross section at which a rising water level just begins to flow out of the channel and over the floodplain.

Township - The Township of Spring, Berks County, Pennsylvania.

Township Engineer - A professional engineer licensed as such in the Commonwealth of Pennsylvania, duly appointed as the engineer for the Township.

Vernal Pond – Seasonal depressional wetlands that are covered by shallow water for variable periods from winter to spring, but may be completely dry for most of the summer and fall.

Watercourse - A channel or conveyance of surface water having defined bed and banks, whether natural or artificial, with perennial or intermittent flow.

Waters of the Commonwealth - Any and all rivers, streams, creeks, rivulets, ditches, watercourses, storm sewers, lakes, dammed water, wetlands, ponds, springs, and all other bodies or channels of conveyance of surface and underground water, or parts thereof, whether natural or artificial, within or on the boundaries of this Commonwealth.

Watershed - Region or area drained by a river, watercourse or other body of water, whether natural or artificial.

Wellhead – 1. a structure built over a well, 2. the source of water for a well.

Wellhead Protection Area - The surface and subsurface area surrounding a water supply well, well field, spring or infiltration gallery supplying a public water system, through which contaminants are reasonably likely to move toward and reach the water source.

Wet Basin - Pond for urban runoff management that is designed to detain urban runoff and always contains water.

Wetland - Those areas that are inundated or saturated by surface or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions, including swamps, marshes, bogs, fens, and similar areas.

(Ordinance No. 355, March 24, 2008, Section 1)

Stormwater Management

Section 301. General Requirements.

- (A) Applicants proposing regulated activities in the Township of Spring which do not fall under the exemption criteria shown in Section 402 shall submit a drainage plan consistent with the applicable Watershed Stormwater Management Plan to the Township for review. These criteria shall apply to the total proposed development even if development is to take place in stages.
- (B) All regulated activities involving an increase in impervious cover, a diversion of stormwater runoff crossing or leaving a site, or an alteration to the existing groundcover, shall be conducted in conformance with the provisions of this Chapter.
- (C) The Applicant is required to evaluate practicable alternatives to the surface discharge of stormwater, the creation of impervious surfaces and the degradation of waters of the Commonwealth, and must maintain as much as possible the natural hydrologic regime
- (D) The Drainage Plan must be designed consistent with the sequencing provisions of Section 304 to ensure maintenance of the natural hydrologic regime and to promote groundwater recharge and protect groundwater and surface water quality and quantity. The Drainage Plan designer must proceed sequentially in accordance with Part 3 of this Chapter.
- (E) Existing points of concentrated drainage that discharge onto adjacent property shall not be altered in any manner which could cause property damage without permission of the affected property owner(s) and shall be subject to any applicable discharge criteria specified in this Chapter.
- (F) Areas of existing diffused drainage discharge shall be subject to any applicable discharge criteria in the general direction of existing discharge, whether proposed to be concentrated or maintained as diffused drainage areas, except as otherwise provided by this Chapter. If diffused drainage discharge is proposed to be concentrated and discharged onto adjacent property, the Applicant must document that adequate downstream conveyance facilities exist to safely transport the concentrated discharge, or otherwise prove that no erosion, sedimentation, flooding or other impacts will result from the concentrated discharge.

- (G) Where a development site is traversed by existing watercourses, drainage easements shall be provided conforming to the line of such watercourses. The terms of the easement shall conform to the stream buffer requirements contained in Section 306(F) of this Chapter.
- (H) Any stormwater management facilities regulated by this Chapter that would be located in or adjacent to waters of the Commonwealth or wetlands shall be subject to approval by PaDEP through the Joint Permit Application process, or, where deemed appropriate by PaDEP, the General Permit process. When there is a question whether wetlands may be involved, it is the responsibility of the Applicant or his agent to show that the land in question cannot be classified as wetlands, otherwise approval to work in the area must be obtained from PaDEP.
- (I) Any stormwater management facilities that would be located within State highway rights-of-way or any alteration that affects stormwater flow directly or indirectly toward a PennDOT facility shall be subject to PennDOT regulations.
- (J) Minimization of impervious surfaces and infiltration of runoff through seepage beds, infiltration trenches, etc. are encouraged, where soil conditions permit, to reduce the size or eliminate the need for detention facilities or other structural BMPs.
- (K) Roof drains shall not be connected to impervious surfaces in order to promote overland flow and infiltration/ percolation of stormwater where advantageous to do so. When site conditions preclude infiltration/percolation, then it shall be permitted on a case by case basis by the Township.
 - (L) All stormwater runoff shall be treated for water quality
- (M) Transference of runoff to or from an EV/HQ watershed is prohibited unless otherwise authorized by PaDEP, DRBC or SRBC.

<u>Section 302. Requirements by Other Government Entities</u>. All activities regulated by this Chapter must comply with any and all applicable local, county, state and federal regulations. (Ordinance No. 355, March 24, 2008, Section 1)

Section 303. Erosion and Sediment Pollution Control During Regulated Earth Disturbance Activities.

(A) Whenever the vegetation and topography are to be disturbed, such activity must be in conformance with Chapter 102, Title 25, Rules and Regulations,

- Part I, Commonwealth of Pennsylvania, Department of Environmental Protection, Subpart C, protection of natural Resources, Article II, Water Resources, Chapter 102, "Erosion Control,".
- (B) No Regulated Earth Disturbance activities within the Township shall commence until the Township receives an approval from the Conservation District of an Erosion and Sediment Pollution Control Plan for construction activities.
- (C) PaDEP has regulations that require an Erosion and Sediment Pollution Control Plan for any earth disturbance activity of 5,000 square feet or more, under 25 Pa. Code § 102.4(b).
- (D) In addition, under 25 Pa. Code Chapter 92, a PaDEP "NPDES Construction Activities" permit is required for Regulated Earth Disturbance activities.
- (E) Evidence of any necessary permit(s) for Regulated Earth Disturbance activities from the appropriate PaDEP regional office or County Conservation District must be provided to the Township. The issuance of an NPDES Construction Permit (or permit coverage under the statewide General Permit (PAG-2) satisfies the requirements subsection 303.(A).
- (F) A copy of the Erosion and Sediment Pollution Control plan and any required permit, as required by PaDEP regulations, shall be available at the project site at all times.
- (G) Additional erosion and sediment pollution control design standards and criteria, recommended to be applied where infiltration BMPs are proposed, shall include the following:
 - (1) Areas proposed for infiltration BMPs shall be protected from sedimentation and compaction during the construction phase to maintain maximum infiltration capacity.
 - (2) Infiltration BMPs shall not be constructed nor receive runoff until the entire contributory drainage area to the infiltration BMP has achieved final stabilization
- (H) Erosion and sediment pollution control devices shall be installed concurrently with earthmoving activities and whenever a situation is created which would contribute to increased erosion.

- (I) No earthmoving or stripping of vegetation will be conducted in areas of greater than thirty-three (33) percent slope unless specific approval is obtained from the Township.
- (J) Earthmoving and the addition of fill shall be maintained where possible and practicable to preserve desirable natural features and the topography of the site. Changes in grade and topography and other earthmoving shall be in accordance with the approved Erosion and Sediment Pollution Control Plan.
- (K) Stripping of vegetation, regrading or other development shall be done in such a way that will minimize erosion.
- (L) All clearing and grading operations shall comply with the requirements for Tree Preservation included in Chapter 32 (the Township of Spring Zoning Ordinance).
 - (1) Land disturbance shall be limited to the actual construction site and an access strip. The amount of disturbed area and the duration of exposure shall be kept to a practical minimum.
 - (2) To the maximum extent practicable, mature healthy trees of at least six (6) inches trunk width measured three (3) feet above the average surrounding ground level shall be retained and protected. Such trees shall not be removed except as provided on the approved subdivision or land development plan and in accordance with the applicable provisions of Chapter 32 (the Township of Spring Zoning Ordinance). The filling of soil over the roots of trees to be preserved is prohibited. (The roots are presumed to extend out from the tree as far as the tree's branches extent outward.)
- (M) Procedures for protecting soils or geologic structures with water supply potential from contamination by surface water or other disruption by construction activity shall be established in consultation with the Township and such areas shall include, at minimum, those underlain by carbonate limestone formations. The Township may require pollution control facilities to be provided on existing and proposed stormwater management systems within or adjacent to the project site
- (N) Provisions for protecting existing wells or other water supplies shall be established.
- (O) Unless otherwise permitted, graded slopes shall not be steeper than three (3) horizontal units to one (1) vertical unit.

- (P) A minimum of four (4) inches of topsoil shall be provided on all disturbed areas prior to final seeding and mulching.
- (Q) Adequate erosion protection shall be provided along all open channels, and at all points of discharge (PaDEP Erosion, Sediment and Pollution Control Manual).
- (R) Sediment and erosion pollution control facilities shall be designed according to applicable governmental standards, specifically the following:
 - (1) PaDEP sediment and erosion control plan requirements in Chapter 102, Title 25 [Pa.Code].
 - (2) Berks County Conservation District standards, which has been delegated by the Pennsylvania Department of Environmental Protection to enforce the erosion and sediment pollution control plan.
 - (3) It shall be the responsibility of the applicant to submit the application and other necessary material to the Berks County Conservation District. Comments shall be received and compliance therewith accomplished prior to final plan approval.

Section 304. Nonstructural Project Design (Sequencing to Minimize Stormwater Impacts).

- (A) For projects disturbing one (1) acre or more, the design of all Regulated Activities shall include evaluation of practicable alternatives to the surface discharge of stormwater, the creation of impervious surfaces, and the degradation of waters of the Commonwealth, and must maintain as much as possible the natural hydrologic regime of the site.
 - (1) An alternative is practicable if it is available and capable of being done after taking into consideration cost, existing technology and logistics in light of overall project purposes, and other Township requirements.
 - (2) All practicable alternatives to the discharge of stormwater are presumed to have less adverse impact on quantity and quality of waters of the Commonwealth unless otherwise demonstrated.

- (B) The Applicant shall demonstrate that the design of Regulated Activities that disturb one (1) acre or more include the following issues:
 - (1) Preparation of an Existing Resource and Site Analysis Map (ERSAM), showing environmentally sensitive areas including, but not limited to, steep slopes, ponds, lakes, streams, wetlands, hydric soils, vernal pools, flood plains, stream buffer zones, hydrologic soil groups A and B (areas conducive to infiltration), areas of limestone or karst geology, special geologic features, any existing recharge areas and any other requirements outlined in the Township Subdivision and Land Development Ordinance.
 - (2) Establishment of appropriate buffers for each of the delineated environmentally sensitive areas per the Township Zoning Ordinance and this Ordinance (See Section 306(F) for stream buffers and Section 310(K) for special geologic feature buffers).
 - (3) Preparation of a draft project layout avoiding sensitive areas identified in Section 304(B)(1).
 - (4) Identification of site specific existing conditions drainage areas, discharge points, recharge areas and hydrologic soil groups A and B.
 - (5) Evaluation of Nonstructural Stormwater Management Alternatives
 - (a) Minimization of earth disturbance
 - (b) Minimization of impervious surfaces
 - (c) Break up of large impervious surfaces.
 - (6) Compliance with the infiltration objective (Section 305) and provisions for stormwater pretreatment prior to infiltration. Pretreatment may not be necessary for rooftop runoff which enters the infiltration facility directly from a roof leader.
 - (7) Compliance with water quality provisions (Section 306) and streambank erosion protection objective (Section 307).
 - (8) Determination of applicable Management District Section 1004) and performance of an existing conditions runoff analysis.

- (9) Preparation of final project design to maintain existing conditions drainage areas and discharge points, to minimize earth disturbance and impervious surfaces, and to the maximum extent possible, to ensure the remaining site development has no surface or point discharge.
- (10) Performance of a proposed conditions runoff analysis based on the final design, and meeting the release rate and the overbank flow and extreme event requirements (Section 308).
- (11) Management of any remaining runoff through treatment prior to discharge, as part of detention, bioretention, direct discharge or other structural control.

Section 305. Ground Water Recharge (Infiltration/Recharge/Bioretention). Maximizing the ground water recharge capacity of the area being developed is required. Design of the infiltration stormwater management facilities shall give consideration to providing ground water recharge to compensate for the reduction in the percolation that occurs when the ground surface is disturbed or impervious surface is created. It is recommended that roof runoff be directed to infiltration BMPs which can be over-designed to compensate for runoff from, and infiltration losses due to, parking areas. These measures are required to be consistent with Section 103, and take advantage of utilizing any existing recharge areas.

Infiltration may not be feasible on every site due to site-specific limitations such as soil type. If it cannot be physically accomplished, due to seasonal high water table, soil permeability rate, soil depth or setback distances from special geologic features, then the design professional shall be responsible to show that this cannot be physically accomplished. If it can be physically accomplished, then the volume of runoff to be infiltrated shall be determined from Sections 305(A)(3) depending on demonstrated site conditions and shall be the greater of the two volumes.

(A) Infiltration BMPs shall meet the following minimum requirements:

(1) Infiltration Requirements. Regulated activities will be required to infiltrate, where site conditions permit, a portion of the runoff created by the development as part of an overall stormwater management plan designed for the site. The volume of runoff to be infiltrated shall be determined from Sections 305.(A)(3)(a) or 305.(A)(3)(b), depending upon demonstrated site conditions.

- (2) Infiltration BMPs intended to receive runoff from developed areas shall be selected based on suitability of soils and site conditions and shall be constructed on soils that have the following characteristics:
 - (a) A minimum depth of 24 inches between the bottom of the BMP and the limiting zone.
 - (b) An infiltration and/or percolation rate sufficient to accept the additional stormwater load and drain completely as determined by field tests conducted by the Applicant's design professional.
 - (c) The infiltration facility shall be capable of completely infiltrating the required retention (infiltration) volume within 4 days (96 hours).
 - (d) Pretreatment shall be provided prior to infiltration. The pretreatment shall be designed to protect the infiltration system from clogging prior to scheduled maintenance and to protect groundwater quality
- (3) The size of the infiltration facility shall be based upon the following volume criteria:
 - (a) NRCS Curve Number equation.

The NRCS runoff equation shall be utilized to calculate infiltration requirements (I) in inches.

I (Infiltration requirement, in inches) = (200 / CN) - 2

Eqn: 305.1

Where:

CN = SCS (NRCS) curve number of existing conditions contributing to the infiltration facility.

This equation is displayed graphically in, and the infiltration requirement can be determined from Figure 305.1.

It has been determined that infiltrating 0.46 inches of runoff from the impervious areas will aid in maintaining the hydrologic regime of the watershed. However, the rounded number 0.5 inches will be used.




Figure 305.1. Infiltration requirement based upon NRCS Curve Number.

The retention (infiltration) volume (Re_v) required to meet the infiltration requirement would therefore be computed as:

$$Re_v = (0.5 \text{ or I, whichever is greater})^* \text{ impervious area (square feet) / (12 in/ft) = Cubic Feet}$$

Eqn: 305.2

Where:

I = infiltration requirements (in inches.)

(b) Annual Recharge - Water Budget Approach.

If the goals of Sections 305.(A)(3)(a) cannot be achieved, then 0.5 inches of rainfall shall be infiltrated from all impervious areas, up to an existing site conditions curve number of 81. Above a curve number of 81, Equation 305.1 or the curve in

Figure 305.1 should be used to determine the infiltration requirement.

The retention (infiltration) volume (Re_v) required again would therefore be computed as:

 $Re_v = (0.5 \text{ or I, whichever is greater}) * impervious area (sq.ft.) / (12in/ft) = Cubic Feet.$

- (B) Soils A detailed soils evaluation of the project site shall be required where practicable to determine the suitability of infiltration facilities. The evaluation shall be performed by a qualified design professional, and at a minimum, address soil permeability, depth to bedrock, presence of special geologic features and subgrade stability. The general process for designing the infiltration BMP shall be:
 - (1) Analyze hydrologic soil groups as well as natural and manmade features within the site to determine general areas of suitability for infiltration practices. In areas where development on fill material is under consideration, conduct geotechnical investigations of sub-grade stability; infiltration is not permitted to be ruled out without conducting these tests.
 - (2) Provide field tests such as double ring infiltrometer or hydraulic conductivity tests (at the level of the proposed infiltration surface) to determine the appropriate hydraulic conductivity rate. Percolation tests are not recommended for design purposes.
 - (3) Design the infiltration structure for the required retention (Re_v) volume based on field determined capacity at the level of the proposed infiltration surface.
 - (4) If on-lot infiltration structures are proposed by the Applicant's design professional, it must be demonstrated to the Township that the soils are conducive to infiltrate on the lots identified.
- (C) Carbonate Areas The Applicant is required to investigate the ability of all areas on the site which are not underlain by carbonate rock to meet the infiltration requirements of Section 305(A). If this investigation proves infeasible, infiltration may occur on areas underlain by carbonate rock. Nevertheless, extreme caution shall be exercised where infiltration is proposed in geologically susceptible areas. Design of such infiltration facilities shall follow the recommended procedure below in conjunction with Figure B-1 in Section 1002 (Appendix B); however, the Applicant is not required to use infiltration in carbonate areas even if the site falls into the

"Recommended" range on Figure B-1 in Section 1002 (Appendix B). If infiltration is not proposed, the calculated infiltration volume (Section 305(A)) shall be treated by an acceptable BMP.

Infiltration BMP loading rate percentages in Figure B-1 in Section 1002 (Appendix B) shall be calculated as follows:

$$\left(\frac{\text{Area tributary to the infiltration BMP}}{\text{Base Area of the infiltration BMP}}\right) * 100\%$$

The area tributary to the infiltration BMP shall be weighted as follows:

Area Description	Weighting
All disturbed area to be made impervious	100%
All disturbed areas to be made pervious	50%
All undisturbed impervious areas	100%
All undisturbed pervious areas	0%

Soil thickness is to be measured from the bottom of any proposed infiltration BMP. The effective soil thickness in Figure B-1 in Section 1002 (Appendix B) is the measured soil thickness multiplied by the thickness factor based on soil permeability, as follows:

Permeability Range	Thickness Factor
6.0 to 12.0 inches/hr	0.8
2.0 to 6.0 inches / hr	1.0
1.0 to 2.0 inches/hr	1.4
0.75 to 1.0 inches/hr	1.2
0.5 to 0.75 inches/hr	1.0

The design of all facilities over Karst shall include an evaluation of measures to minimize adverse effects.

(D) Stormwater Hotspots – Following is a list of examples of designated hotspots. If a site is designated as a hotspot, it has important implications for how stormwater is managed. First and foremost, untreated stormwater runoff from hotspots shall not be allowed to recharge into groundwater where it may contaminate water supplies. Therefore, the Re_v requirement shall NOT be applied to development sites that fit into the hotspot category (the entire WQv must still be treated). Second, a greater level of stormwater treatment shall be considered at hotspot sites to prevent pollutant washoff after construction. EPA's NPDES stormwater program requires some industrial sites to prepare and implement a stormwater pollution prevention plan.

Examples of Hotspots:

- (1) Vehicle salvage yards and recycling facilities
- (2) Vehicle fueling stations
- (3) Vehicle service and maintenance facilities
- (4) Vehicle and equipment cleaning facilities
- (5) Fleet storage areas (bus, truck, etc.)
- (6) Industrial sites (based on Standard Industrial Codes)
- (7) Marinas (service and maintenance)
- (8) Outdoor liquid container storage
- (9) Outdoor loading/unloading facilities
- (10) Public works storage areas
- (11) Facilities that generate or store hazardous materials
- (12) Commercial container nursery
- (13) Other land uses and activities as designated by an appropriate review authority

The following land uses and activities are not normally considered hotspots:

- (1) Residential streets and rural highways
- (2) Residential development
- (3) Institutional development
- (4) Office developments
- (5) Non-industrial rooftops
- (6) Pervious areas, except golf courses and nurseries (which may need an Integrated Pest Management (IPM) Plan).

While large highways (average daily traffic volume (ADT) greater than 30,000) are not designated as a stormwater hotspot; it is important to ensure that highway stormwater management plans adequately protect groundwater.

- (E) Caution shall be exercised where infiltration is proposed in Source Water Protection Areas as defined by the Township or local Water Authority/Provider.
- (F) Infiltration facilities shall be used in conjunction with other innovative or traditional stormwater control facilities that are found within the PaDEP State BMP Manual.
- (G) Caution shall be exercised where salt or chloride (municipal salt storage) would be a pollutant since soils do little to filter this pollutant and it may contaminate the groundwater. The qualified design professional shall evaluate the possibility of groundwater contamination from the proposed infiltration facility and perform a hydrogeologic justification study if necessary.
- (H) The infiltration requirement in High Quality or Exceptional Value waters shall be subject to the Department's Chapter 93 Antidegradation Regulations.
- (I) Dependant upon certain land uses or hotspots an impermeable liner will be required in detention basins where the possibility of groundwater contamination exists. A detailed hydrogeologic investigation may be required by the Township.
- (J) The Township shall require the Applicant to provide safeguards against groundwater contamination for land uses that may cause groundwater contamination should there be a mishap or spill.
- (K) For projects that disturb one (1) acre or more, unless greater setbacks are specified in the Zoning Ordinance, the following setbacks for infiltration facilities shall apply:
 - (1) 100 feet from water supply wells;
 - (2) 10 feet downslope or 100 feet upslope from building foundations;
 - (3) 50 feet from septic system drainfields;

- (4) 100 feet from a geologic contact with carbonate bedrock, unless a preliminary site investigation is done in the carbonate bedrock to show the absence of special geologic features within 100 feet of the proposed infiltration area; and
- (5) 100 feet from the property line unless documentation is provided to show all setbacks from wells, foundations and drainfields on the neighboring property will be met.

(Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 306. Water Quality Requirements.</u> The applicant shall comply with the following water quality requirements of this Part.

(A) Developed areas shall provide adequate storage and treatment facilities necessary to capture and treat stormwater runoff. The infiltration volume computed under Section 305 may be a component of the water quality volume if the Applicant chooses to manage both components in a single facility. If the infiltration volume is less than the water quality volume, the remaining water quality volume may be captured and treated by methods other than infiltration BMPs. The required water quality volume (WQ $_v$) is the storage capacity needed to capture and treat a portion of stormwater runoff from the developed areas of the site.

To achieve this goal, the following criterion is established:

The following calculation formula is to be used to determine the water quality storage volume, (WQ_v), in acre-feet of storage for any watershed within the Township of Spring:

$WQ_v = [(P)(R_v)(A)]/12$	Eqn: 306.1		_
---------------------------	------------	--	---

 $WQ_v = Water Quality Volume (acre-feet)$

P = 1 inch

A = Total contributing drainage area to the water quality BMP (acres) $R_v = 0.05 + 0.009(I)$ where I is the percent of the area that is impervious

surface ((impervious area/A)*100)

This volume requirement can be accomplished by the permanent volume of a wet basin or the detained volume from other BMPs.

Release of water can begin at the start of the storm (i.e., the invert of the water quality orifice is at the invert of the facility). The design of the facility

shall provide for protection from clogging and unwanted sedimentation.

- (B) For areas within defined Special Protection subwatersheds which include Exceptional Value (EV) and High Quality (HQ) waters, Cold Water Fishery (CWF) the temperature and quality of water and streams shall be maintained.
- (C) To accomplish the above, the Applicant shall use innovative or traditional stormwater control facilities that are found within the PaDEP State BMP Manual.
- (D) If a perennial or intermittent stream passes through the site, the applicant shall create a stream buffer extending a minimum of fifty (50) feet to either side of the top-of-bank of the channel. The buffer area shall be maintained with appropriate native vegetation (Reference to Appendix H of Pennsylvania Handbook of Best Management Practices for Developing Area for plant lists). If the applicable rear or side yard setback is less than fifty (50) feet, the buffer width may be reduced to twenty-five (25) percent of the setback to a minimum of ten (10) feet. However, in no case shall such buffer be less in width than that specified for a riparian buffer in the Township Zoning Ordinance. If an existing buffer is legally prescribed (i.e. deed, covenant, easement, etc.) and it exceeds the requirements of this Chapter, the existing buffer shall be maintained. This does not include lakes or wetlands.
- (E) Evidence of any necessary permit(s) for regulated earth disturbance activities from the appropriate PaDEP regional office must be provided to the Township. The issuance of an NPDES Construction Permit (or permit coverage under the statewide General Permit (PAG-2) satisfies the requirements of subsection 306(A).
- (F) In selecting the appropriate BMPs or combinations thereof, the land developer SHALL consider the following:
 - (1) Total contributing area.
 - (2) Permeability and infiltration rate of the site soils.
 - (3) Slope and depth to bedrock.
 - (4) Seasonal high water table.
 - (5) Proximity to building foundations and well heads.
 - (6) Erodibility of soils.
 - (7) Land availability and configuration of the topography.

- (G) The following additional factors SHOULD be considered when evaluating the suitability of BMPs used to control water quality at a given development site:
 - (1) Peak discharge and required volume control.
 - (2) Stream bank erosion.
 - (3) Efficiency of the BMPs to mitigate potential water quality problems.
 - (4) The volume of runoff that will be effectively treated.
 - (5) The nature of the pollutant being removed.
 - (6) Maintenance requirements.
 - (7) Creation/protection of aquatic and wildlife habitat.
 - (8) Recreational value.
 - (9) Enhancement of aesthetic and property value.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 307. Streambank Erosion Requirements. In addition to control of the water quality volume, in order to minimize the impact of stormwater runoff on downstream streambank erosion, the primary requirement is to design a BMP to detain the proposed conditions 2-year, 24-hour design storm to the existing conditions 1-year peak flow using the SCS Type II distribution. Additionally, provisions shall be made (such as adding a small orifice at the bottom of the outlet structure) so that the proposed conditions 1-year storm takes a minimum of 24 hours to drain from the facility from a point where the maximum volume of water from the 1-year storm is captured. (i.e., the maximum water surface elevation is achieved in the facility). Release of water can begin at the start of the storm (i.e., the invert of the water quality orifice is at the invert of the facility).

The minimum orifice size in the outlet structure to the BMP shall be a three (3) inch diameter orifice and a trash rack shall be installed to prevent clogging. On sites with small contributing drainage areas to this BMP that do not provide enough runoff volume to allow a 24-hour attenuation with the 3 inch orifice, the calculations shall be submitted showing this condition. Orifice sizes less than 3 inches can be utilized provided that the design will prevent clogging of the intake. (Ordinance No. 355, March 24, 2008, Section 1)

Section 308. Stormwater Management Districts.

(A) The Watersheds within the Township of Spring have been divided into stormwater management districts as shown on the Management District Map(s) in Section 1004 (Appendix D).

In addition to the requirements specified in Tables 308.1a through 308.1.d below, the groundwater recharge (Section 305), water quality (Section 306), and streambank erosion control (Section 307), requirements shall be implemented.

Standards for managing runoff from each subarea in the Schuylkill River, Tulpehocken Creek, Cocalico Creek and Conestoga River Watersheds for all required design storms are shown in Tables 308.1.a through 308.1.d. Development sites located in each of the Districts must control proposed conditions runoff rates to existing conditions runoff rates for the design storms in accord with Tables 308.1.a through 308.1.d.

TABLE 308.1.a – Water Quantity Requirements - Schuylkill River Watershed

Management District	Proposed Condition Design Storm		Existing Condition Design Storm
	2-year		1-year
	5- year	Dodge Te	5-year
A [10-year		10-year
A	25-year	Reduce To	25-year
	50-year		50-year
<u> </u>	100-year		100-year
	2-year		1-year
	5-year	Reduce To	2-year
В	10-year		5-year
l b [25-year		10-year
	50-year		25-year
	100-year		50-year
 	2-year	+	1-year
	5-year	Reduce To	5-year
С	10-year		10-year
	25-year		25-year
	50-year		50-year
	100-year		100-year

TABLE 308.1.b - Water Quantity Requirements-Tulpehocken Creek Watershed

Management District	Proposed Condition Design Storm		Existing Condition Design Storm
	2-year		1-year
A	5- year	Reduce To	5-year
A [10-year		10-year
	25-year		25-year
			-
	2-year		1-year
B-1	5-year	— Kediice Io — — — — — — — — — — — — — — — — — —	2-year
D-1	10-year		5-year
	25-year		10-year
С	2-year	Reduce To	1-year
	5-year		2-year

EXPLANATION OF DISTRICT C: Development sites which can discharge directly to the Tulpehocken Creek main channel or major tributaries or indirectly to the main channel through an existing stormwater drainage system (i.e., storm sewer or tributary) may do so without control of post-development peak rate of runoff greater than the 5-year storm. If the post-development runoff is intended to be conveyed by an existing stormwater drainage system to the main channel, assurance must be provided that such system has adequate capacity to convey the increased peak flows or will be provided with improvements to furnish the required capacity. When adequate capacity of downstream system does not exist and will not be provided through improvements, the post-development peak rate of runoff must be controlled to the pre-development peak rate as required in District A provisions (i.e.,10-year post-development flows to 10 pre-development flows) for the specified design storms.

TABLE 308.1.c - Water Quantity Requirements-Cocalico Creek Watershed

Post-development rates of runoff from any regulated activity within the Cocalico Creek Watershed shall not exceed 50% of the peak rates of runoff prior to development for all design storms unless the pre-existing hydrograph is not exceeded at all points in time.

TABLE 308.1.d - Water Quantity Requirements - Conestoga River Watershed

Management District	Proposed Condition Design Storm		Existing Condition Design Storm
Α	All Design Storms	Reduce To	30% of Peak Flow for All Design Storms
В	All Design Storms	Reduce To	50% of Peak Flow for All Design Storms

All areas, regardless of the release rate, must still meet the requirements of the groundwater recharge criteria (Section 305), water quality criteria (Section 306), and streambank erosion criteria (Section 307).

- (B) General Proposed condition rates of runoff from any regulated activity shall not exceed the peak release rates of runoff prior to development for the design storms specified on the Stormwater Management District Watershed Map(s) (Section 1004 (Appendix D)) and Section 308, of this Chapter.
- (C) District Boundaries The boundaries of the Stormwater Management Districts are shown on an official map that is available for inspection at the Township office. A copy of the official map at a reduced scale is included in Section 1004 (Appendix D). The exact location of the Stormwater Management District boundaries as they apply to a given development site shall be determined by mapping the boundaries using the two-foot topographic contours (or most accurate data required) provided as part of the Drainage Plan.
- (D) Sites Located in More Than One District For a proposed development site located within two or more stormwater management district category subareas, the peak discharge rate from any subarea shall meet the Management District Criteria for which the discharge is located, as indicated in Section 308. The calculated peak discharges shall apply regardless of whether the grading plan changes the drainage area by subarea. An exception to the above may be granted if discharges from multiple subareas recombine in proximity to the discharge site. In this case, peak discharge in any direction shall follow Management District A criteria provided that the overall site discharge meets the Management District Criteria for which the discharge is located.

- (E) Off-Site Areas Off-site areas that drain through a proposed development site are not subject to release rate criteria when determining allowable peak runoff rates. However, on-site drainage facilities shall be designed to safely convey off-site flows through the development site.
- (F) Site Areas Where the site area to be impacted by a proposed development activity differs significantly from the total site area, only the proposed impact area utilizing stormwater management measures shall be subject to the Management District Criteria. In other words, unimpacted areas bypassing the stormwater management facilities would not be subject to the Management District Criteria.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 309. Calculation Methodology.

(A) Stormwater runoff from all development sites with a drainage area of greater than 200 acres shall be calculated using a generally accepted calculation technique that is based on the NRCS soil cover complex method. Table 309-1 summarizes acceptable computation methods and the method selected by the design professional shall be based on the individual limitations and suitability of each method for a particular site. The Rational Method shall be used to estimate peak discharges from drainage areas that contain less than 200 acres. The Soil Complex Method shall be used for drainage areas greater than 200 acres.

TABLE 309-1 Acceptable Computation Methodologies For Stormwater Management Plans

METHOD	METHOD DEVELOPED BY	APPLICABILITY	
TR-20 (or commercial computer package based on TR-20)	USDA NRCS	Applicable where use of full hydrology computer model is desirable or necessary.	
TR-55 (or commercial computer package based on TR-55)	USDA NRCS	Applicable for land development plans within limitations described in TR-55.	
HEC-1 / HEC-HMS	US Army Corps of Engineers	Applicable where use of full hydrologic computer model is desirable or necessary.	
PSRM	Penn State University	Applicable where use of a hydrologic computer model is desirable or necessary; simpler than TR-20 or HEC-1.	
Rational Method (or commercial computer package based on Rational Method)	Emil Kuichling(1889)	For sites less than 200 acres and with time of concentration less than 60 minutes (tc< 60 min), or as approved by the Township.	
Other Methods	Varies	Other computation methodologies approved by the Township.	

*Note: Successors to the above methods are also acceptable. These successors include WinTR55 for TR-55 and WinTR20 for TR-20 and SWMM

- (B) All calculations consistent with this Chapter using the soil cover complex method shall use the appropriate design rainfall depths for the various return period storms according to the region in which they are located as presented in Table B-1 in Appendix B of this Chapter. If a hydrologic computer model such as PSRM or HEC-1 / HEC-HMS is used for stormwater runoff calculations, then the duration of rainfall shall be 24 hours. The rainfall distribution should reference to NOAA Atlas 14.
 - (C) For the purposes of existing conditions flow rate determination,

undeveloped land shall be considered as "meadow" in good condition, unless the natural ground cover generates a lower curve number or Rational 'C' value (i.e., forest), as listed in Table B-1 or B-2 in Section 1002 (Appendix B) of this Chapter. In such cases, values representing the actual ground cover shall be utilized. Average antecedent moisture conditions shall apply to existing condition calculations.

- (D) All calculations using the Rational Method shall use rainfall intensities consistent with appropriate times-of-concentration for overland flow and return periods from the NOAA Atlas 14 Precipitation-Frequency Atlas of the United States (2004, revised 2006). When approved by the Township, rainfall intensities may be based upon the current PennDOT Storm Intensity-Duration-Frequency chart for Region 4.Times-of-concentration for overland flow shall be calculated using the methodology presented in Chapter 3 of Urban Hydrology for Small Watersheds, NRCS, TR-55 (as amended or replaced from time to time by NRCS). Times-of-concentration for channel and pipe flow shall be computed using Manning's equation. NRCS lag equation divided by 0.6 as acceptable method for Tc in undeveloped areas.
- (E) Times of concentration shall be based on the following design parameters:
 - (1) Sheet flow: The maximum length for each reach of sheet or overland flow before shallow concentrated or open channel flow develops is one hundred fifty (150) feet. Flow lengths greater than one hundred (100) feet shall be justified based on the actual conditions at each development site. The maximum construction phase and post-development sheet flow length for unpaved surfaces shall be one hundred (100) feet for most situations (one hundred fifty (150) feet for areas which will remain undisturbed).
 - (2) Shallow concentrated flow: Travel time for shallow concentrated flow shall be determined using Figure 3-1 from TR-55, Urban Hydrology for small watersheds, as shown in Appendix B6.
 - (3) Open Channel flows: At points where sheet and shallow concentrated flows concentrate in field depressions, swales, gutters, curbs, or pipe collection systems, the travel times and downstream end of the development site between these design points shall be based upon Manning's Equation and/or acceptable engineering design standards as determined by the municipal engineer.
 - (F) Runoff Curve Numbers (CN) for both existing and proposed

conditions to be used in the soil cover complex method shall be obtained from Table B-1 in Section 1002 (Appendix B) of this Chapter.

- (G) Runoff coefficients (c) for both existing and proposed conditions for use in the Rational method shall be obtained from Table B-2 in Section 1002 (Appendix B) of this Chapter.
- (H) Where uniform flow is anticipated, the Manning equation shall be used for hydraulic computations, and to determine the capacity of open channels, pipes, and storm sewers. Values for Manning's roughness coefficient (n) shall be consistent with Table B-3 in Section 1002 (Appendix B) of the Chapter. Full flow shall be assumed for closed conduits.
- (I) Outlet structures for stormwater management facilities shall be designed to meet the performance standards of this Chapter using any generally accepted hydraulic analysis technique or method.
- (J) The design of any stormwater detention facilities intended to meet the performance standards of this Chapter shall be verified by routing the design storm hydrograph through these facilities using the Storage-Indication Method. This shall be performed for both the post-development and construction phase conditions. For drainage areas greater than 200 acres in size, the design storm hydrograph shall be computed using a calculation method that produces a full hydrograph (i.e. TR-20, TR-55, HEC-1, PSRM). The Township may approve the use of any generally accepted full hydrograph approximation technique that shall use a total runoff volume that is consistent with the volume from a method that produces a full hydrograph.
- (K) During the construction progression of a project, the discharge of stormwater runoff from the site may follow distinct patterns that will be altered during the course of the construction. In such an event, the comparison of the construction phase discharge rate to the predevelopment rate shall be performed for each separate and distinct pattern. At no time throughout the construction phase of a project shall the peak discharge rate discharging from any location along the boundary of a site exceed the predevelopment peak discharge rate at that location.
- (L) Where applicable, construction phase and post-development time of concentration to a storage facility shall be the time of concentration in the storm sewer to its point of discharge into the storage facility. Overland flow from the discharge point to the outlet structure shall not be included in the time of concentration.

- (M) When designing regional storage facilities for office parks, industrial parks, etc., the following design criteria shall be followed:
 - (1) Assumed impervious, lawn, etc., coverage areas shall be noted in the calculations for each lot which will drain to the basin. Impervious coverage shall be assumed to be the maximum coverage allowed by Chapter 32 (the Zoning Ordinance).
 - (2) A six (6.0) minute time of concentration shall be used to calculate the post-development basin inflow hydrographs (five (5.0) minutes for rational method). Longer times of concentration shall be allowed only where significant portions of the drainage area will remain undeveloped or where it can be demonstrated that the longer times will occur even after the full potential development.
 - (3) For lots which will have on lot detention or retention basins, the predevelopment time of concentration for the lot shall be the same as the predevelopment time of concentration for the entire predevelopment drainage area in which it is located.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 310. Other Requirements.

(A) General requirements

- (1) For any of the activities regulated by this Chapter, including the preliminary or final approval of subdivision and/or land development plans, the management of stormwater on the site, both during and upon completion of the proposed disturbances, shall be accomplished in accordance with the standards and criteria of this Chapter.
- (2) The design of any temporary or permanent facilities and structures and the utilization of any natural drainage systems shall be in full compliance with these terms and the interpretations of the Township.
- (3) Any facilities that constitute water obstructions (e.g., culverts, bridges, outfalls, or stream enclosures), water encroachments, and any work involving wetlands governed by PaDEP Chapter 105 regulations (as amended or replaced from time to time by PaDEP), are subject to PaDEP Chapter 105 regulations.

- (4) Any proposed roadway drainage facilities shall be designed according to PennDOT Design Manual Part II.
- (5) The Township reserves the right to disapprove any design that would result in the construction in or continuation of a stormwater problem area.
- (6) All stormwater management facilities shall comply with the applicable provisions of the Township of Spring Construction Manual and Standard Specifications.
- (7) Any developer shall be responsible for the control of surface water from his property to a point of natural disposal. It shall be the responsibility of the applicant to obtain, from adjacent property owners, any easements or other necessary property interests concerning flowage of water from the proposed development onto private lands. The construction of improvements necessary to control runoff and prevent property damage may be required. Whenever practicable, the easement shall be parallel with and conjunctive to property lines of the project site.
- (8) All streets shall be so designed as to provide for the discharge of surface water from their rights-of-way.
- (9) The slope of the crown on proposed streets shall not be less than one-eighth (1/8) inch per foot and not more than one-third (1/3) inch per foot.
- (10) Increases or decreases in the hydrology of natural wetlands or changes to the function of wetlands shall be minimized to the maximum extent practical. Where such changes are proposed, the impact of the proposal on wetland functional values shall be assessed using standard methods appropriate to the affected wetland.

(B) Detention and Retention Basin Design

(1) Any stormwater management facility (i.e., detention basin, retention basins) designed to store runoff and requiring a berm or earthen embankment required or regulated by this Chapter shall be designed to provide an emergency spillway to handle flow up to and including the 100-year proposed conditions and may be subject to PaDEP Chapter 105 regulations.

- (2) No stormwater detention or retention facility shall be placed within fifty (50) feet of a special geologic feature.
- (3) Whenever a basin will be located in an area underlain by limestone, a geological evaluation of the proposed location shall be conducted to determine susceptibility to sinkhole formations. The design of all facilities over limestone formations shall include measures to prevent ground water contamination and, where necessary, sinkhole formation. The Township may require the installation of an impermeable liner in detention or retention basins. A detailed hydrogeologic investigation may be required by the Township.
- (4) It shall be the developer's responsibility to verify if the site is underlain by limestone. The following note shall be attached to all drainage plans and signed and sealed by the professional responsible for confirming the site's geologic conditions:

"I,		, a registered	of the
Commonwealth	of Pennsylva	ania, do hereby certify	that the proposed
detention basin ((circle one) is	s/is not underlain by	limestone."

- (5) Basins shall be installed prior to any earthmoving or land disturbances which they will serve. The phasing of their construction shall be noted in the narrative and on the plan.
- (6) Energy dissipators and/or level spreaders shall be installed at points where pipes or drainageways discharge to or from basins.
- (7) Interior and exterior slopes of compacted soil shall not exceed one (1) foot vertical for three (3) feet horizontal, and may be further reduced if the soil has unstable characteristics. Unless otherwise required to comply with PaDEP regulations, the minimum bottom slope shall be two (2) percent for grass and seventy-five hundredths (0.75) percents for concrete paving. One (1) percent may be used for grass if an underdrain system is provided. A concrete low flow channel shall be required for all basins where the distance from the inlet pipe to the outlet structure exceeds one hundred (100) feet. The minimum channel width shall be four (4) feet and the design must be approved by the Township.
- (8) Detention and retention basins shall also be designed to meet the following requirements:
 - (a) The minimum top of berm width shall be eight (8) feet.

- (b) Outlet pipes shall have a minimum diameter of twelve (12) inches. For pipe lengths exceeding one hundred (100) feet, the minimum diameter shall be fifteen (15) inches.
- (c) Properly spaced antiseep collars shall be installed on all basin outlet pipes. Design calculations shall be provided.
- (9) A key trench at least 2 feet deep, or extending down to stable subgrade, whichever is deeper, of compacted relatively impervious material (Unified Soil Classification CL or ML) shall be provided. Minimum bottom width for the key trench shall be 4 feet. Maximum side slopes for the key trench shall be one horizontal to one vertical. A compacted impervious core at least 8 feet wide at the top, having a maximum side slope of one horizontal to one vertical, shall extend for the full length of the embankment, and the top elevation shall be set at the design year water surface elevation.
- (10) All pipes and culverts through embankments shall have properly spaced anti-seep collars (minimum 6 inch thick).
- (11) Outlet structures within basins which will control peak discharge flows and distribute the flows by plans to discharge areas shall be constructed of reinforced concrete, and shall have childproof, nonclogging trash racks over all design openings twelve (12) inches in diameter, except those openings designed to carry perennial stream flows.
- (12) Emergency spillways shall be constructed of concrete of sufficient mass and structural stability to withstand the pressures of impounded waters and outlet velocities. Precast concrete paving blocks and sod may be used when approved by the Township. Emergency spillways shall be designed to safely convey the one hundred (100) year basin inflow hydrograph through the basin assuming the principal outlet is completely blocked, and a minimum one (1) foot freeboard shall be provided. Should any stormwater management facility require a dam safety permit under PaDEP Chapter 105, the facility shall be designed in accordance with Chapter 105 and meet the regulations of Chapter 105 concerning dam safety which may be required to pass storms larger than the 100-year event.
- (13) Inlet and outlet structures shall be located at maximum distances from one another. The Township may require a rock filter berm or rock-filled gabions between inlet and outlet areas when the distance is deemed insufficient for sediment trappings.

- (14) Permanent grasses or stabilization measures shall be established on the sides of all earthen basins by hydroseeding within five (5) days of initial construction. The Township may require jute or erosion control matting to be installed inside the basin or on the basin embankment.
- (15) Adequate drainage courses shall be provided and maintained for the discharge(s) from the basin. If the basin will not discharge to a suitable natural drainage course, the Township may require the developer to provide facilities to safely and efficiently convey the discharge to asuitable drainage course. Securing of necessary drainage easements for this purpose shall be the sole responsibility of the developer.
- (16) When PaDEP requires facilities to have a State permit, the designer shall submit all information to PaDEP and obtain all necessary approval and permits. No stormwater facility shall create health or sanitation problems. Consideration shall be given to safety standards.
- (17) When deemed necessary by the Board of Supervisors, stormwater detention facilities shall be enclosed with a fence of a type approved by the Board of Supervisors.
- (18) Paved surfaces that are to serve as stormwater storage areas shall have minimum grades of 1/2% and shall be restricted to storage depths of 1/2 feet maximum. If a portion of an area within a stormwater storage area is to be paved for parking or recreational purposes, the paved surface shall be placed at the highest elevation with the storage area as possible.
- (19) The following additional conditions shall be complied with for wet bottom stormwater storage areas:
 - (a) Water surface area shall not exceed 1/10 of the tributary drainage area,
 - (b) Shoreline protection shall be provided to prevent erosion from wave action.
 - (c) Minimum normal water depth shall be 4 feet. If fish are to be used to keep the pond clean, a minimum of 1/4 of the pond area shall be a minimum of 10 feet deep.
 - (d) Facilities shall be provided to allow the pond level to be lowered by gravity flow for cleaning purposes and shoreline maintenance.

- (e) Aeration facilities as may be required to prevent pond stagnation shall be provided. Design calculations to substantiate the effectiveness of these aeration facilities shall be submitted with final engineering plans. Agreements for the perpetual operation and maintenance of aeration facilities shall be prepared to the satisfaction of the municipality.
- (f) In the event that the water surface of the pond is to be raised for the purposes of storing water for irrigation or in anticipation of the evapotranspiration demands of dry weather, the volume remaining for storage of excess stormwater runoff shall still be sufficient to contain the design year storm runoff.

(C) Collection and Conveyance System Design

- (1) Storm sewers must be able to convey proposed conditions runoff from a 25-year design storm without flooding inlets, where appropriate.
- (2) No stormwater conveyance facility shall be constructed within fifty (50) feet of a special geologic feature, unless it is constructed of durable pipe utilizing watertight joints.
- (3) Storm sewers, culverts, bridges and related installations shall be provided:
 - (a) To permit unimpeded flow of natural watercourses. Such flow may be redirected as required, subject to the approval of PaDEP.
 - (b) To insure adequate drainage of all low points along the line of streets.
 - (c) To intercept stormwater runoff along streets at intervals reasonably related to the extent and grade of the area drained, and to prevent substantial flow of water across intersections or flooded intersections during the specified design storm.
 - (d) To insure adequate and unimpeded flow of stormwater under driveways in, near or across natural watercourses or drainage swales. Suitable pipes or other waterway openings shall be provided as necessary.

- (4) Storm sewers, as required, shall be placed under or immediately in front of the curb, when parallel to the street within the right-of-way. Generally, locating storm sewers under curbs in curves or at street intersections shall be prohibited. When located in undedicated land, they shall be placed within an easement not less than twenty (20) feet wide as approved by the Township Engineer.
- (5) Storm sewer systems shall have curb inlets located at curb tangents on the uphill side of street intersections and at other locations as may be required by the Township as necessary to intercept runoff'. Design and location of curb inlets shall be in accordance with Pennsylvania Department of Transportation Design Manual Part 2.
- (6) Storm sewers shall be installed in accordance with the following requirements:
 - (a) All storm sewers shall be constructed per PennDOT Form 408 Specifications and Design Manual, Part 2, Highway Design and Standards for Roadway Construction, unless otherwise directed by the Township.
 - (b) Storm sewers shall have a minimum diameter of fifteen (15) inches and a minimum slope of one-half (1/2) percent.
 - (c) Storm sewers at design flows shall have a minimum velocity of 2.5 fps and a maximum velocity of 12.0 fps.
 - (d) Reinforced concrete pipe is acceptable for all storm sewer construction. Corrugated polyethylene pipe will be permitted for diameters of fifteen (15) inches to thirty-six (36) inches only. Pipe materials shall be subject to approval by the Township.
 - (e) All storm sewer pipe within street cartways or other paved areas shall be bedded and backfilled in accordance with the provisions of the Township of Spring Construction Manual and Standard Specification.
- (7) Storm sewers shall be designed based upon the following criteria:
 - (a) Any changes in alignment shall be accomplished utilizing straight sections connected by inlets or manholes.

- (b) When there is a change in pipe size through a structure, the top inside elevation of the outlet pipe shall be at or below the elevations of all incoming pipes.
- (c) Storm sewers shall be sized to handle the flow anticipated during the 25-year design storm. Where inlets or storm sewers are designed to drain low points in streets or other areas, or wherever stormwater amounts exceeding the capacity of the proposed conveyance facilities would cause potential erosion or damage to property, overflow facilities capable of handling the calculated 100-year flows are required.
- (d) Storm sewer design shall be based upon PennDOT design methods. Inlet efficiency and bypass flow shall be determined for all inlets, and the gutter flow spread shall not exceed one-half (1/2) the travel lane width.
- (e) Where necessary, storm sewers and culverts shall be evaluated for inlet and outlet control restrictions.
- (8) Inlets shall conform to PennDOT standards. Precast concrete inlets may be used but the Township Engineer must approve these inlets for each project.
 - (a) Inlets shall generally be located at the lowest point of street intersections to intercept the stormwater before it reaches pedestrian crossings or at sag point of vertical curves in the street alignment which provides a natural point of ponding of surface stormwater.
 - (b) At street intersections, inlets shall be placed in the tangent and not the curved portion of the curbing.
 - (c) Inlets shall be designed and located to prevent hazards to vehicles, bicycles and pedestrians.
 - (d) Where the Township deems it necessary because of special land requirements, special inlets may be approved.
 - (e) The interval between inlets serving stormwater runoff flow along the curb shall not exceed a maximum of one thousand (1,000) feet when located along any one (1) continuous curb line. More

frequent spacing shall be required when the entrance capacity of any individual inlet warrants closer spacing as determined by calculations which incorporate consideration of the area drained, intensity of rainfall, slope or grade, runoff coefficient of imperviousness and cross-sectional rear of the gutter.

- (f) When inlets are used in a storm system within the rightof-way limits of a street, in lieu of manholes, the spacing of such inlets shall not exceed the maximum distance of four hundred fifty (450) feet along any one (1) continuous line.
- (9) Manholes shall be installed in accordance with the following requirements:
 - (a) The construction locations of manholes shall be as indicated on the subdivision drainage plan or area drainage plan approved by the governing municipal authorities.
 - (b) Manholes shall be located on a continuous storm sewer system at all abrupt changes of grade, at all locations where a transition in storm sewer pipe sizing is required, at all angle points and at all points of convergence of two (2) or more influent storm sewer mains.
 - (c) Manholes shall not be more than three (300) feet apart on sizes up to twenty-four (24) inches and not more than four hundred fifty (450) feet apart on larger sizes. Inlets may be substituted for manholes on approval by the Township.
- (10) The construction of endwalls shall be required at ends of all stormwater conveyance structures.
 - (a) Special care shall be used by the design engineer to select the proper endwall to fit the condition.
 - (b) The design engineer shall provide energy dissipators at endwalls where the discharge velocity with pipe flowing full is more than one (1) fps.
- (11) Stormwater roof drains shall not discharge water directly over a sidewalk or into any sanitary sewer line.

- (12) Bridges and culverts shall have ample waterway to carry expected flows, based on a minimum storm frequency of twenty-five (25) years. Bridge and/or culvert construction shall be in accordance with the PennDOT specifications and shall meet the requirements of DEP.
 - (a) Culverts shall be provided with wing walls and constructed for the full width of the right-of-way. The cartway area over the bridge shall be 24 inches wider, on either side, than the road connecting with the bridge, or if the character of the road is expected to change for future planning, the cartway of the bridge shall be made to anticipate this condition. On either side of the bridge cartway, the bridge railing must be set back from the edge of the final cartway and this area may be used to place sidewalks, present or future.
- (13) Provisions shall be made to prevent erosion within watercourses and at points of discharge from storm drainage facilities into watercourses. The velocity of the discharge into a watercourse shall not exceed 0.5 feet/second perpendicular to the axis of the watercourse and 1.0 feet/second parallel to the axis of the watercourse.
- (14) Design of open channels and swales shall comply with the following:
 - (a) Open ditches will not be permitted but properly designed, graded and turfed drainage swales shall be permitted in lieu of storm sewers, where approved by the Township,. Swales shall be located within an easement not less than twenty (20) feet wide, but of sufficient width to allow access for maintenance.
 - (b) Such swales shall be designed not only to carry the required 25-year storm discharge completely contained within the channel bottom and banks without excessive erosion, but also to increase the time of concentration, reduce the peak discharge and velocity and permit the water to percolate into the soil. The minimum grassed swale grade shall be one (1) percent and all swales shall be designed with a minimum six (6) inches of freeboard. For grass swales the minimum design flow velocity shall be two (2.0) fps, and PennDOT approved turf reinforcement mat shall be installed where design velocities exceed four (4) fps.
 - (c) Swales shall be designed in accordance with the Channel Design procedures found in the Department of Environmental

Protection Bureau of Water Quality Protection, Erosion and Sediment Pollution Control Program Manual.

- (d) All open channels shall be designed to convey the 25-year stormwater flow. In addition, open channels shall be design to convey the 100-year stormwater flow from emergency spillways and areas where damage to property would result.
- (e) Open channels located adjacent to streets shall be limited to a top width of 6-feet, depth of 1.5-feet, and if trapezoidal in cross section, a minimum bottom width of 2-feet.

(D) Miscellaneous

- (1) All wet basin designs shall incorporate biologic minimization controls consistent with the West Nile Guidance found in Section 1006 (Appendix F).
- (2) Where pervious pavement is permitted for parking lots, recreational facilities, non-dedicated streets, or other areas, pavement construction specifications shall be noted on the plan.
- (3) Intercepting underdrains shall be required at all locations in which subsurface water is encountered which may permeate or endanger the subgrade of the street. Underdrains shall be required in all cuts three (3) feet deep and greater, and in all other locations stipulated by the Township Engineer. Pipe foundation underdrains shall be parallel to the established street grade to outlet in approved drainage structures. Pipe foundation underdrain shall consist of a trench excavated to a minimum depth of twenty-four (24) inches below the underneath elevation of the special subgrade and to the minimum width of eighteen (18) inches in which a six (6) inch pipe underdrain shall be laid. The trench shall be backfilled with Pennsylvania Department of Transportation 2B aggregate to its full depth around and above the laid pipe.
- (4) If the length of pipe underdrain exceeds six hundred (600) feet in one (1) run, the minimum diameter of six (6) inches shall be increased to eight (8) [inches] beyond that point. Pipe shall meet PennDOT, Form 408 Specifications.

(Ordinance No. 355, March 24, 2008, Section 1)

PART 4

Drainage Plan Requirements

Section 401. General Requirements. For any of the activities regulated by this Chapter, the preliminary or final approval of subdivision and/or land development plans, the issuance of any building or occupancy permit, or the commencement of any earth disturbance activity may not proceed until the Property Owner or Applicant or his/her agent has received written approval of a Drainage Plan from the Township unless the project qualifies for an exemption from the requirements to submit a Drainage Plan. (Ordinance No. 355, March 24, 2008, Section 1)

Section 402. Exemptions.

- (A) General Exemptions. The following land use activities are exempt from the drainage plan submission requirements of this Chapter:
 - (1) Use of land for gardening for home consumption.
 - (2) Agricultural plowing and tilling are exempt from the rate control and SWM site plan preparation requirements of this Chapter provided the activities are performed according to the requirements of 25 PA Code, Chapter 102.
 - (3) Forest Management and timber operations are exempt from the rate control and SWM site plan preparation requirements of this Chapter provided the activities are performed according to the requirements of 25 PA Code, Chapter 102 and the applicable provisions of Chapter 32 (the Township of Spring Zoning Ordinance).
 - (4) Regulated activities that create disconnected Impervious Areas smaller than 1000 sq feet are exempt from the Peak Rate Control and the SWM Site Plan preparation requirements of this Chapter.
- (B) Stormwater Quantity Control Exemption. Any Regulated Activity that meets the impervious area exemption criteria in Table 402-1 shall not be required to implement the stormwater quantity controls, specified in Section 308 of this Chapter. These criteria shall apply to the total development even if development is to take place in phases. The date of the adoption of this Chapter shall be the starting point from which to consider tracts as "parent tracts" in which future subdivisions and respective impervious area computations shall be cumulatively considered. Impervious areas existing on the "parent tract" prior to

adoption of this Chapter shall not be considered in cumulative impervious area calculations for exemption purposes.

TABLE 402-1 Impervious Area Exemption Criteria

Total Parcel Size	Impervious Area Exemption (sq.ft.)
0 to <0.125 ac	1,000 sq. ft.
0.125 to <0.5 ac	2,500 sq. ft.
0.5 to <1 ac	5,000 sq. ft.
1 to <2 ac	7,500 sq. ft.
2 to <3 ac	10,000 sq. ft.
3 to <4 ac	12,500 sq. ft.
≥ 4 ac	15,000 sq. ft.

Submissions for projects that utilize the exemption under section 402(B) shall still be required to meet the groundwater recharge (Section 305), water quality (Section 306), and streambank erosion (Section 307) controls of this Chapter. Drainage plans in accordance with Sections 403(A)(2), 403(B)(7), (8), (11), (15), and (22) and 403(D)(2) must still be submitted. Any exemption must first be approved by the Township.

(C) Additional Exemption Requirement:

- (1) Exemption responsibilities An exemption shall not relieve the Applicant from implementing such measures as are necessary to protect the public health, safety, and property. An exemption shall not relieve the Applicant from providing adequate stormwater management for Regulated Activities to meet the requirements of this Chapter.
- (2) HQ and EV streams This exemption shall not relieve the Applicant from meeting the special requirements for watersheds draining to high quality (HQ) or exceptional value (EV) waters, identified and Source Water Protection Areas (SWPA) and requirements for nonstructural project design sequencing (Section 304), groundwater recharge (Section 305), water quality (Section 306), and streambank erosion (Section 307).
- (3) Drainage Problems If a drainage problem is documented or known to exist downstream of, or expected from the proposed activity, then the Township may require a drainage plan submittal.

All regulated activities occurring in drainage areas tributary to waters designated HQ/EV pursuant to 25 PA Code, Chapter 93, shall not change any biological, chemical, or physical characteristics, including volume, rate, velocity, course, current, cross section, or temperature of the waters, unless the activity is specifically permitted in accordance with the environmental laws of the Commonwealth.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 403. Drainage Plan Contents. The Drainage Plan shall consist of a general description of the project including sequencing items described in Section 304, calculations, maps and plans. A note on the maps shall refer to the associated computations and erosion and sediment control plan by title and date. The cover sheet of the computations and erosion and sediment control plan shall refer to the associated maps by title and date. All Drainage Plan materials shall be submitted to the Township in a format that is clear, concise, legible, neat, and well organized; otherwise, the Drainage Plan shall not be accepted for review and shall be returned to the Applicant.

The following items shall be included in the Drainage Plan:

(A) General

- (1) General description of the project including those areas described in <u>Section 304</u>.
- (2) General description of permanent stormwater management techniques, including construction specifications of the materials to be used for stormwater management facilities.
- (3) A description of any storm drainage problems within, adjacent to or downstream of the project site.
- (4) Complete hydrologic, hydraulic, and structural computations for all stormwater management facilities.
- (5) An Erosion and Sediment Pollution Control Plan, including all reviews and approvals by the Conservation District.
 - (6) A general description of nonpoint source pollution controls.
- (B) Maps. Map(s) of the project area shall be submitted on 24-inch x 36-inch sheets and/or shall be prepared in a form that meets the requirements for recording at the offices of the Recorder of Deeds of Berks County. If the Township

Subdivision and Land Development Ordinance (SALDO) has more stringent criteria, then the more stringent criteria shall apply. The contents of the map(s) shall include, but not be limited to:

- (1) The location of the project relative to highways, municipalities or other identifiable landmarks.
- (2) Existing contours at intervals of two feet. In areas of steep slopes (greater than 15 percent), five-foot contour intervals may be used.
- (3) Existing streams, lakes, ponds or other Waters of the Commonwealth within the project area.
- (4) Other physical features including flood hazard boundaries, stream buffers, existing drainage courses, areas of natural vegetation to be preserved, potential or delineated wetland areas, areas of limestone geology, special geologic features and the total extent of the upstream area draining through the site.
- (5) The locations of all existing and proposed utilities, sanitary sewers, and water lines within fifty (50) feet of property lines.
- (6) An overlay showing soil names and boundaries, identifying those soils which are hydric, have seasonal high water tables, or shallow depth to bedrock.
- (7) Limits of earth disturbance, proposed changes to the land surface and vegetative cover, including the type and amount of impervious area that would be added.
 - (8) Proposed structures, roads, paved areas, and buildings.
- (9) Final contours at intervals of two feet. In areas of steep slopes (greater than 15 percent), five-foot contour intervals may be used.
- (10) The name of the development, the name and address of the owner of the property, and the name of the individual or firm preparing the plan.
 - (11) The date of submission.
- (12) A graphic and written scale of one (1) inch equals no more than fifty (50) feet; for tracts of twenty (20) acres or more, the scale shall be one (1)

inch equals no more than one hundred (100) feet. Alternative scales may be utilized if pre-approved by the Township.

- (13) A north arrow.
- (14) The total tract boundary and size with distances marked to the nearest foot and bearings to the nearest degree.
 - (15) Existing and proposed land use(s).
- (16) A key map showing all off site existing man-made features which may be affected by stormwater runoff or stormwater management controls for the project.
 - (17) Location of all open channels.
- (18) Overland drainage patterns and swales, flowpaths used in calculations for time of concentration.
- (19) A minimum twenty-foot wide access easement around all stormwater management facilities that would provide ingress to and egress from a public right-of-way.
- (20) The location of all erosion and sediment pollution control facilities.
- (21) A note on the plan indicating the location and responsibility for maintenance of all stormwater management facilities, including those that are located off-site. All facilities, whether on or off-site, shall meet the performance standards and design criteria specified in this Chapter.
- (22) A statement, signed by the landowner, acknowledging that any revision to the approved Drainage Plan must be approved by the Township and the Conservation District.
 - (23) The following signature block for the Design Engineer:
 - "I, (Design Engineer), on this date (date of signature), hereby certify that the Drainage Plan meets all design standards and criteria of the Township of Spring Stormwater Management Chapter."
- (C) Supplemental Information. The following supplemental information shall be provided with the Drainage Plan.

- (1) A written description of the following information shall be submitted:
 - (a) The overall stormwater management concept for the project designed in accordance with <u>Section 304</u>.
 - (b) Stormwater runoff computations as specified in this Chapter.
 - (c) A summary comparing peak rates of runoff at all points of discharge from the site for the predevelopment, construction phase and post development conditions.
 - (d) Stormwater management techniques to be applied both during and after development.
 - (e) Expected project time schedule.
 - (f) Development stages (project phases) if so proposed.
- (2) An operation and maintenance plan in accordance with Sections 403(E) and 702 of this Chapter.
- (3) An erosion and sediment pollution control plan, including all reviews and approvals, as required by PaDEP and the Berks County Conservation District.
- (4) The effect of the project (in terms of runoff volumes and peak flows) on adjacent properties and on any existing Township stormwater collection system that may receive runoff from the project site.
- (5) A copy of the Highway Occupancy permit and all reviews and approvals from PennDOT when utilization of a PennDOT drainage system or improvements within a state right-of-way is proposed.
- (D) Stormwater Management Facilities.
- (1) All stormwater management facilities must be located on a plan and described in detail.
- (2) When infiltration facilities such as seepage pits, beds or trenches are used, the locations of existing and proposed septic tank infiltration areas and wells must be shown.

- (3) All calculations, assumptions, and criteria used in the design of the stormwater management facilities must be shown.
- (E) Responsibilities for Operations and Maintenance of Stormwater Controls and BMPs.
 - (1) No Regulated Earth Disturbance activities within the Township shall commence until approval by the Township of a Stormwater Control and BMP Operations and Maintenance plan which describes how the permanent (e.g., post-construction) stormwater controls and BMPs will be properly operated and maintained.
 - (2) The following items shall be included in the Stormwater Control and BMP Operations and Maintenance Plan:
 - (a) Map(s) of the project area, in a form that meets the requirements for recording at the offices of the Recorder of Deeds of Berks County, and shall be submitted on 36-inch x 48-inch sheets. The contents of the maps(s) shall include, but not be limited to:
 - i) Clear identification of the location and nature of permanent stormwater controls and BMPs,
 - ii) The location of the project site relative to highways, municipal boundaries or other identifiable landmarks,
 - iii) Existing and final contours at intervals of two feet, or others as appropriate,
 - iv) Existing streams, lakes, ponds, or other bodies of water within the project site area,
 - v) Other physical features including flood hazard boundaries, sinkholes or other special geologic features, streams, existing drainage courses, potential or delineated wetland areas, and areas of natural vegetation to be preserved,
 - vi) The locations of all existing and proposed utilities, sanitary sewers, and water lines within 50 feet of property lines of the project site,

- vii) Proposed final changes to the land surface and vegetative cover, including the type and amount of impervious area that would be added,
- viii) Proposed final structures, roads, paved areas, and buildings, and
- ix) A fifteen-foot wide access easement around all stormwater controls and BMPs that would provide ingress to and egress from a public right-of-way.
- (b) A description of how each permanent stormwater control and BMP will be operated and maintained, and the identity of the person(s) responsible for operations and maintenance,
- (c) The name of the project site, the name and address of the owner of the property, and the name of the individual or firm preparing the plan, and
- (d) A statement, signed by the landowner, acknowledging that the stormwater controls and BMPs are fixtures that can be altered or removed only after approval by the Township.
- (3) The Stormwater Control and BMP Operations and Maintenance Plan for the project site shall establish responsibilities for the continuing operation and maintenance of all permanent stormwater controls and BMPs, as follows:
 - (a) Only where stormwater controls or BMPs are deemed by the Board of Supervisors to be regional in nature, or where the Township determines that it is in the best interest of the general public, shall the Township accept operations and maintenance responsibility for stormwater controls or BMPs located outside of the public street rights-of-way;
 - (b) The responsibility for operations and maintenance of all other stormwater controls or BMPs, whether by the property owner, a property owners association, or a private management entity, shall be specified on the Operations and Maintenance Plan.
- (4) The Township shall make the final determination on the continuing operations and maintenance responsibilities. The Township reserves the right to accept or reject the operations and maintenance

responsibility for any or all of the stormwater controls and BMPs.

- (F) Township Review of Stormwater Control and BMP Operations and Maintenance Plan.
 - (1) The Township shall review the Stormwater Control and BMP Operations and Maintenance Plan for consistency with the purposes and requirements of this Chapter, and any permits issued by PaDEP.
 - (2) The Township shall notify the Applicant in writing whether the Stormwater Control and BMP Operations and Maintenance Plan is approved.
 - (3) The Township may require a "Record As-built Drawing" of all stormwater controls and BMPs, and an explanation of any discrepancies with the Operations and Maintenance Plan.
 - (4) All agreements, easements, covenants or other similar documents, which assign operations and maintenance responsibility for stormwater controls or BMPs, shall be provided to the Township Solicitor for review and approval.

(Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 404. Plan Submission.</u> The Township shall require receipt of a complete plan, as specified in this Chapter.

For any activities that require an NPDES Permit for Stormwater Discharges from Construction Activities, a PaDEP Joint Permit Application, a PennDOT Highway Occupancy Permit, or any other permit under applicable state or federal regulations or are regulated under Chapter 105 (Dam Safety and Waterway Management) or Chapter 106 (Floodplain Management) of PaDEP's Rules and Regulations, the proof of application for said permit(s) or approvals shall be part of the plan. The plan shall be coordinated with the state and federal permit process and the Township SALDO review process.

- (A) For projects which require SALDO approval, the Drainage Plan shall be submitted by the Applicant as part of the Preliminary Plan submission where applicable for the Regulated Activity.
- (B) For these regulated activities that do not require SALDO approval, see Section 401, General Requirements.

- (C) Six (6) copies of the Drainage Plan shall be submitted and distributed as follows:
 - (1) Two (2) copies to the Township accompanied by the requisite Township Review Fee, as specified in this Chapter.
 - (2) Two (2) copies to the Conservation District.
 - (3) One (1) copy to the Township Engineering and Planning Department.
 - (4) One (1) copy to the County Planning Commission, when directed by the Township.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 405. Drainage Plan Review.

- (A) The Township shall review the Drainage Plan with the standards set forth in the Township's Stormwater Management Ordinance for consistency with the adopted Act 167 Stormwater Management Plans and with all other applicable provisions of this Chapter. Any found incomplete shall not be accepted for review and shall be returned to the Applicant.
- (B) For activities regulated by this Chapter, the Township shall notify the Applicant in writing, within ninety (90) calendar days of receipt of a complete application, whether the Drainage Plan is consistent with the applicable provisions of this Chapter.
 - (1) Should the Drainage Plan be determined to be consistent with the applicable provisions of this Chapter, the Township shall forward an approval letter to the Applicant.
 - (2) Should the Drainage Plan be determined to be inconsistent with the applicable provisions of this Chapter, the Township shall forward a disapproval letter to the Applicant. The disapproval letter shall cite the reason(s) and specific Chapter sections for the disapproval. Disapproval may be due to inadequate information to make a reasonable judgment as to compliance with the stormwater management plan. Any disapproved Drainage Plans may be revised by the Applicant and resubmitted consistent with this Chapter.

- (C) For Regulated Activities specified in Section 104 of this Chapter, which require a building permit, the Township Engineering and Planning Department shall notify the Township Building Code Official in writing, within a time frame consistent with the Township Building Code and/or Township Subdivision and Land Development Ordinance, whether the Drainage Plan is consistent with the applicable provisions of this Chapter and forward a copy of the approval/disapproval letter to the Applicant. Any disapproved drainage plan may be revised by the Applicant and resubmitted consistent with this Chapter.
- (D) For regulated activities under this Chapter that require an NPDES Permit Application, the Applicant shall forward a copy of the Township's letter stating that the Drainage Plan is consistent with the applicable stormwater management plan to the Conservation District. PaDEP and the Conservation District may consider the Township's review comments in determining whether to issue a permit.
- (E) The Township shall not grant approval or grant preliminary approval to any subdivision or land development for Regulated Activities specified in Section 105 of this Chapter if the Drainage Plan has been found to be inconsistent with the applicable provisions of this Chapter, as determined by the Township. All required permits from PaDEP must be obtained prior to approval of any subdivision or land development.
- (F) The Township Building Code Official shall not issue a building permit for any Regulated Activity under this Chapter if the Drainage Plan has been found to be inconsistent with the provisions of this Chapter, as determined by the Township Engineering and Planning Department, or without considering the comments of the Township Engineering and Planning Department. All required permits from PaDEP must be obtained prior to issuance of a building permit.
- (G) The Applicant shall be responsible for completing record as-built drawings of all stormwater management facilities included in the approved Drainage Plan. The record as-built drawings and an explanation of any discrepancies with the design plans shall be submitted to the Township for final approval. The Township may withhold approval of the record as-built drawings until the Township receives a copy of an approved Highway Occupancy Permit from the PennDOT District Office, NPDES Permit, and any other applicable permits or approvals, from PaDEP or the Conservation District. The above permits and approvals must be based on the record drawings.
- (H) The Township's approval of a Drainage Plan shall be valid for a period not to exceed five (5) years, commencing on the date that the Township issues an approval letter for the Drainage Plan. For subdivisions and land developments, the

5-year time period shall commence on the date that the plan is officially approved by the Board of Supervisors. If stormwater management facilities included in the approved Drainage plan have not been constructed, or if constructed, and record asbuilt drawings of these facilities have not been approved within this 5-year time period, then the Township may consider the Drainage Plan disapproved and may revoke any and all permits. Drainage Plans that are considered disapproved by the Township shall be resubmitted in accordance with Section 407 of this Chapter.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 406. Modification of Plans.

- (A) A modification to a Drainage Plan under review by the Township for a development site that involves a change in stormwater management facilities or techniques, or that involves the relocation or re-design of stormwater management facilities, or that is necessary because soil or other conditions are not as stated on the Drainage Plan as determined by the Township, shall require a resubmission of the modified Drainage Plan consistent with Section 404 of this Chapter and be subject to review as specified in Section 405 of this Chapter.
- (B) A modification to an already approved or disapproved Drainage Plan shall be submitted to the Township, accompanied by the applicable Township Review and Inspection Fee. A modification to a Drainage Plan for which a formal action has not been taken by the Township shall be submitted to the Township, accompanied by the applicable Township Review and Inspection Fee.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 407. Resubmission of Disapproved Drainage Plans. A disapproved Drainage Plan may be resubmitted, with the revisions addressing the Township's concerns documented in writing and addressed to the Township Secretary in accordance with Section 404 of this Chapter and distributed accordingly and be subject to review as specified in Section 405 of this Chapter. The applicable Township Review and Inspection Fee must accompany a resubmission of a disapproved Drainage Plan. (Ordinance No. 355, March 24, 2008, Section 1)

PART 5

Inspections

Section 501. Schedule of Inspections.

- (A) The Township or their designee shall inspect all phases of the installation of the permanent stormwater management facilities as deemed appropriate by the Township.
- (B) During any stage of the work, if the Township or it's designee determines that the permanent stormwater management facilities are not being installed in accordance with the approved Drainage Plan, the Township shall revoke any existing building permits and issue a cease and desist order until a revised Drainage Plan is submitted and approved except as directed by the Township or Conservation District, as specified in this Chapter.
- (C) A final inspection of all stormwater management facilities shall be conducted by the Township or its' designee and to confirm compliance with the approved Drainage Plan prior to the issuance of any Occupancy Permit.

(Ordinance No. 355, March 24, 2008, Section 1)

PART 6

Fees and Expenses

Section 601. Township Drainage Plan Review and Inspection Fee. Fees shall be established by the Township to defray plan review and construction inspection costs incurred by the Township. All fees shall be paid by the Applicant at the time of Drainage Plan submission. Review and Inspection Fee Schedule shall be established by resolution of the Board of Supervisors based on the size of the Regulated Activity and based on the Township's costs for reviewing Drainage Plans and conducting inspections pursuant to Section 501. The Township shall periodically update the Review and Inspection Fee Schedule to ensure that review costs are adequately reimbursed. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 602</u>. Expenses Covered by Fees. The fees required by this Chapter shall at a minimum cover:

- (A) Administrative costs.
- (B) The review of the Drainage Plan by the Township.
- (C) The site inspections.
- (D) The inspection of stormwater management facilities and drainage improvements during construction.
- (E) The final inspection upon completion of the stormwater management facilities and drainage improvements presented in the Drainage Plan.
- (F) Any additional work required to enforce any permit provisions regulated by this Chapter, correct violations, and assure proper completion of stipulated remedial actions.

(Ordinance No. 355, March 24, 2008, Section 1)

PART 7

Maintenance Responsibilities

Section 701. Performance Guarantee.

- (A) For subdivisions and land developments the Applicant shall provide a financial guarantee to the Township for the timely installation and proper construction of all stormwater management controls as: 1) Required by the approved drainage plan equal to or greater than the full construction cost of the required controls or 2) in the amount and method of payment provided for in the Subdivision and Land Development Ordinance.
- (B) For other regulated activities, the Township may require a financial guarantee from the Applicant.
- (C) At the completion of the project, and as a prerequisite for the release of the performance guarantee, the Applicant or his representatives shall:
 - (1) Provide a certification of completion from an engineer, architect, surveyor or other qualified person verifying that all permanent facilities have been constructed according to the plans and specifications and approved revisions thereto.
 - (2) Provide a set of record as-built drawings.
- (D) After the Township receives the certification, a final inspection shall be conducted by the Township or designee to certify compliance with this Chapter.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 702. Adherence to Approved Stormwater Control and BMP Operations and Maintenance Plan. It shall be unlawful to alter or remove any permanent stormwater control and BMP required by an approved Stormwater Control and BMP Operations and Maintenance Plan, or to allow the property to remain in a condition which does not conform to an approved Stormwater Control and BMP Operations and Maintenance Plan. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 703. Operations and Maintenance Agreement for Privately Owned Stormwater Controls and BMPs.</u>

- (A) The property owner shall sign an operations and maintenance agreement with the Township covering all stormwater controls and BMPs that are to be privately owned. The agreement shall be substantially the same as the agreement in Section 1001 (Appendix A) of this Chapter.
- (B) Other items may be included in the agreement where determined necessary to guarantee the satisfactory operation and maintenance of all permanent stormwater controls and BMPs. The agreement shall be subject to the review and approval of the Township.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 704. Stormwater Management Easements.

- (A) Stormwater management easements are required for all areas used for off-site stormwater control, unless a waiver is granted by the Township.
- (B) Stormwater management easements shall be provided by the property owner, where required by the Township, for areas of on-site stormwater control, for purposes of (1) access for inspections and maintenance, or (2) preservation of stormwater runoff conveyance, infiltration, and detention areas and other stormwater controls and BMPs, by persons other than the property owner. The purpose of the easement shall be specified in any agreement under <u>Section 703</u>.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 705. Recording of Approved Stormwater Control and BMP Operations and Maintenance Plan and Related Agreements.

- (A) The owner of any land upon which permanent stormwater controls and BMPs will be placed, constructed or implemented, as described in the Stormwater Control and BMP Operations and Maintenance Plan, shall record the following documents in the Office of the Recorder of Deeds for Berks County, within 15 days of approval of the Stormwater Control and BMP Operations Plan by the Township:
 - (1) The Operations and Maintenance Plan, or a summary thereof,
 - (2) Operations and Maintenance Agreements under <u>Section 703</u>, and

(3) Easements under Section 704.

(B) The Township may suspend or revoke any approvals granted for the project site upon discovery of the failure of the owner to comply with this Section.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 706. Township Stormwater Control and BMP Operation and Maintenance Fund.

- (A) Persons installing stormwater controls or BMPs shall be required to pay a specified amount to the Township Stormwater Control and BMP Operation and Maintenance Fund to help defray costs of periodic inspections and maintenance expenses. The amount of the deposit shall be determined as follows:
 - (1) If the stormwater control or BMP is to be privately owned and maintained, the deposit shall cover the cost of periodic inspections performed by the Township for a period of ten (10) years, as estimated by the Township. After that period of time, inspections will be performed at the expense of the Township.
 - (2) If the stormwater control or BMP is to be owned and maintained by the Township, the deposit shall cover the estimated costs for maintenance and inspections for ten (10) years. The Township will establish the estimated costs utilizing information submitted by the Applicant.
 - (3) The amount of the deposit to the fund shall be converted to present worth of the annual series values. The Township shall determine the present worth equivalents, which shall be subject to the approval of the Board of Supervisors.
- (B) If a stormwater control or BMP is proposed that also serves as a recreation facility (e.g., ballfield, lake), the Township may reduce or waive the amount of the maintenance fund deposit based upon the value of the land for public recreation purpose.
- (C) If at some future time a stormwater control or BMP (whether publicly or privately owned) is eliminated due to the installation of storm sewers or other storage facility, the unused portion of the maintenance fund deposit will be applied to the cost of abandoning the facility and connecting to the storm sewer system or other facility. Any amount of the deposit remaining after the costs of abandonment are paid will be returned to the depositor.

- (D) If stormwater controls or BMPs are accepted by the Township for dedication, the Township may require persons installing stormwater controls or BMPs to pay a specified amount to the Township Stormwater Control and BMP Operation and Maintenance Fund, to help defray costs of operations and maintenance activities. The amount may be determined as follows:
 - (1) If the stormwater control or BMP is to be owned and maintained by the Township, the amount shall cover the estimated costs for operations and maintenance for ten (10) years, as determined by the Township.
 - (2) The amount shall then be converted to present worth of the annual series values.
- (E) Long-Term Maintenance The Township shall require applicants to pay a fee to the Township Stormwater Maintenance Fund to cover long term maintenance of stormwater control and best management practices.
- (F) Stormwater Related Problems The Township may require applicants to pay a fee to the Township Stormwater Maintenance Fund to cover stormwater related problems which may arise from the land development and earth disturbance. The Township will establish the estimated cost of utilizing information submitted by the Applicant.

PART 8

Prohibitions

Section 801. Prohibited Discharges and Connections.

- (A) Any drain or conveyance, whether on the surface or subsurface, which allows any non-stormwater discharge including sewage, process wastewater, and wash water to enter the waters of this Commonwealth is prohibited.
- (B) No person shall allow, or cause to allow, discharges into surface waters of this Commonwealth which are not composed entirely of stormwater, except (1) as provided in Subsection (c) below, and (2) discharges allowed under a state or federal permit.
- (C) The following discharges are authorized unless they are determined to be significant contributors to pollution to the waters of this Commonwealth:

-	Discharges from fire fighting activities	-	Flows from riparian habitats and wetlands
-	Potable water sources including water line flushing	-	Uncontaminated water from foundations or from footing drains
	Irrigation drainage	-	Lawn watering
-	Air conditioning condensate	-	Dechlorinated swimming pool discharges
,	Springs	-	Uncontaminated groundwater
-	Water from crawl space pumps	•	Water from individual residential car washing
_	Pavement wash waters where spills or leaks of toxic or hazardous materials have not occurred (unless all spill material has been removed)	-	Routine external building wash down (which does not use detergents or other compounds)
	and where detergents are not used		

(D) In the event that the Township or PaDEP determines that any of the discharges identified in Subsection (c), significantly contribute to pollution of the waters of this Commonwealth, the Township or PaDEP will notify the responsible person(s) to cease the discharge.

(Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 802. Roof Drains</u>. Roof drains and sump pumps shall discharge to vegetative BMPs, or to infiltration BMPs (where not located within geologically susceptible areas), and to the maximum extent practicable satisfy the criteria for Disconnected Impervious Areas. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 803.</u> Alteration of SWM BMPs. No person shall modify, remove, fill, landscape, or alter any Stormwater Management BMPs, facilities, areas, or structures, without the written approval of the Township. (Ordinance No. 355, March 24, 2008, Section 1)

PART 9

Enforcement and Penalties

Section 901. Right-of-Entry.

- (A) Upon presentation of proper credentials, duly authorized representatives of the Township may enter at reasonable times upon any property within the Township to inspect the implementation, condition, or operation and maintenance of the stormwater controls or BMPs in regard to any aspect governed by this Chapter.
- (B) Stormwater control and BMP owners and operators shall allow persons working on behalf of the Township ready access to all parts of the premises for the purposes of determining compliance with this Chapter.
- (C) Persons working on behalf of the Township shall have the right to temporarily locate on any stormwater control or BMP in the Township such devices as are necessary to conduct monitoring and/or sampling of the discharges from such stormwater control or BMP.
- (D) Unreasonable delays (greater than 24 hrs.) in allowing the Township access to a stormwater control or BMP is a violation of this Part.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 902. Public Nuisance.

- (A) The violation of any provision of this Chapter is hereby deemed a Public Nuisance.
- (B) Each day that a violation continues shall constitute a separate violation.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 903. General Enforcement.

(A) Whenever the Township finds that a person has violated a prohibition or failed to meet a requirement of this Chapter, the Township may order compliance by written notice to the responsible person. Such notice may require without limitation:

- (1) The performance of monitoring, analyses, and reporting;
- (2) The elimination of prohibited connections or discharges;
- (3) Cessation of any violating discharges, practices, or operations;
- (4) The abatement or remediation of stormwater pollution or contamination hazards and the restoration of any affected property;
- (5) Payment of a fine to cover administrative and remediation costs:
 - (6) The implementation of stormwater controls and BMPs; and
 - (7) Operation and maintenance of stormwater controls and BMPs.
- (B) Such notification shall set forth the nature of the violation(s) and establish a time limit for correction of these violations(s). Said notice may further advise that, if applicable, should the violator fail to take the required action within the established deadline, the work will be done by the Township or designee and the expense thereof shall be charged to the violator.
- (C) Failure to comply within the time specified shall also subject such person to the penalty provisions of this Chapter. All such penalties shall be deemed cumulative and shall not prevent the Township from pursuing any and all other remedies available in law or equity.

Section 904. Suspension and Revocation of Permits and Approvals.

- (A) Any building, land development or other permit or approval issued by the Township may be suspended or revoked, in whole or in part, by the Township for:
 - (1) Non-compliance with or failure to implement any provision of the permit;
 - (2) A violation of any provision of this Chapter; or
 - (3) The creation of any condition or the commission of any act during construction or development which constitutes or creates a hazard or nuisance, pollution or which endangers the life or property of others.

- (B) A suspended permit or approval may be reinstated by the Township, in whole or in part, when:
 - (1) The Township or designee has inspected and approved the corrections to the stormwater controls and BMPs, or the elimination of the hazard or nuisance, and/or;
 - (2) The Township is satisfied that the violation of this Chapter, law, or rule and regulation has been corrected.
- (C) A permit or approval which has been revoked in whole or in part, by the Township cannot be reinstated. The applicant may apply for a new permit under the procedures outlined in this Chapter.

Section 905. Penalties.

- (A) Any person violating the provisions of this Chapter shall be subject to a fine of not less than \$100.00 nor more than \$1,000.00 for each violation, recoverable with costs. Each day that the violation continues shall constitute a separate offense and the applicable fines are cumulative.
- (B) The Township may institute injunctive, mandamus, or any other appropriate action or proceeding at law in equity for the enforcement of this Chapter with the court of competent jurisdiction to obtain restraining orders, temporary or permanent injunctions, mandamus or other appropriate forms of remedy or relief.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 906. Notification. In the event that a person fails to comply with the requirements of this Chapter, or fails to conform to the requirements of any permit issued hereunder, the Township will provide notification of the violation. After notice is provided, failure to correct violations in a timely manner may result in additional violations. (Ordinance No. 355, March 24, 2008, Section 1)

<u>Section 907. Enforcement.</u> The Board of Supervisors is hereby authorized and directed to enforce all of the provisions of this Chapter. All inspections regarding compliance with the drainage plan shall be the responsibility of the Township Engineer or other qualified persons designated by the Township.

- (A) No person shall modify, remove, fill, landscape or alter any Stormwater Management BMPs, facilities, areas, or structures, without the written approval of the Township.
- (B) Upon presentation of proper credentials, the Township may enter at reasonable times upon any property within the Township to inspect the condition of the stormwater structures and facilities in regard to any aspect regulated by this Chapter.
- (C) It shall be unlawful for a person to undertake any Regulated Activity except as provided in an approved Stormwater Management Site Plan, unless specifically exempted from the requirement to submit such Site Plan by this Chapter.
- (D) The Developer shall be responsible for providing record as-built plans of all Stormwater Management BMPs included in the approved Stormwater Management Site Plan. The record as-built plans and an explanation of any discrepancies with the construction plans shall be submitted by the Developer to the Township.
- (E) The record as-built submission shall include a certification of completion signed by a Qualified Professional verifying that all permanent Stormwater Management BMPs have been constructed according to the approved plans and specifications. If any licensed Qualified Professionals contributed to the construction plans, then a licensed Qualified Professional must sign the completion certificate.
- (F) After receipt of the completion certificate by the Township, the Township may conduct a final inspection.
- (G) Inspections regarding compliance with the Stormwater Management Site Plan are a responsibility of the Township.
- (H) The Township may withhold an occupancy permit until a certificate of completion has been provided by the Developer.

Section 908. Appeals.

(A) Any person aggrieved by any action of the Township or its designee may appeal to Board of Supervisors within thirty (30) days of that action.

(B) Any person aggrieved by any decision of Board of Supervisors may appeal to the County Court of Common Pleas in the County where the activity has taken place within thirty (30) days of the Township decision.

(Ordinance No. 355, March 24, 2008, Section 1)

Section 1001. Appendix A – Stormwater Controls and Best Management Practices Operations and Maintenance Agreement. (Ordinance No. 355, March 24, 2008, Section 1)

STORMWATER CONTROLS AND BEST MANAGEMENT PRACTICES OPERATIONS AND MAINTENANCE AGREEMENT

THIS AGREEMENT, made and 200, by and between "Landowner"), and the Township of Spr		(hereinafter the
Pennsylvania 19608 (hereinafter "Towr		i, icading, being county,
W	TITNESSETH	
WHEREAS, the Landowner is the in the land records of Page, (hereinafter "Property").		

WHEREAS, the Landowner is proceeding to build and develop the Property; and

WHEREAS, the Stormwater Controls and BMP Operations and Maintenance Plan approved by the Township (hereinafter referred to as the "Plan") for the property identified herein, which is attached hereto as Appendix A and made part hereof, as approved by the Township, provides for management of stormwater within the confines of the Property through the use of Best Management Practices (BMPs); and

WHEREAS, the Township, and the Landowner, his successors and assigns, agree that the health, safety, and welfare of the residents of the Township and the protection and maintenance of water quality require that on-site stormwater Best Management Practices be constructed and maintained on the Property; and

WHEREAS, for the purposes of this agreement, the following definitions shall apply:

- BMP "Best Management Practice;" activities, facilities, designs, measures or procedures used to manage stormwater impacts from land development, to protect and maintain water quality and groundwater recharge and to otherwise meet the purposes of the Township Stormwater Management Ordinance, including but not limited to infiltration trenches, seepage pits, filter strips, bioretention, wet ponds, permeable paving, rain gardens, grassed swales, forested buffers, sand filters and detention basins.
- Infiltration Trench A BMP surface structure designed, constructed, and maintained for the purpose of providing infiltration or recharge of stormwater into the soil and/or groundwater aquifer,

- Seepage Pit An underground BMP structure designed, constructed, and maintained for the purpose of providing infiltration or recharge of stormwater into the soil and/or groundwater aquifer,
- Rain Garden A BMP overlain with appropriate mulch and suitable vegetation designed, constructed, and maintained for the purpose of providing infiltration or recharge of stormwater into the soil and/or underground aquifer, and

WHEREAS, the Township requires, through the implementation of the Plan, that stormwater management BMPs as required by said Plan and the Township Stormwater Management Ordinance be constructed and adequately operated and maintained by the Landowner, his successors and assigns. And

NOW, THEREFORE, in consideration of the foregoing promises, the mutual covenants contained herein, and the following terms and conditions, the parties hereto agree as follows:

- 1. The BMPs shall be constructed by the Landowner in accordance with the plans and specifications identified in the Plan.
- 2. The Landowner shall operate and maintain the BMP(s) as shown on the Plan in good working order acceptable to the Township and in accordance with the specific maintenance requirements noted on the Plan.
- 3. The Landowner hereby grants permission to the Township, its authorized agents and employees, to enter upon the property, at reasonable times and upon presentation of proper identification, to inspect the BMP(s) whenever it deems necessary. Whenever possible, the Township shall notify the Landowner prior to entering the property.
- 4. In the event the Landowner fails to operate and maintain the BMP(s) as shown on the Plan in good working order acceptable to the Township, the Township or its representatives may enter upon the Property and take whatever action is deemed necessary to maintain said BMP(s). This provision shall not be construed to allow the Township to erect any permanent structure on the land of the Landowner. It is expressly understood and agreed that the Township is under no obligation to maintain or repair said facilities, and in no event shall this Agreement be construed to impose any such obligation on the Township.
- 5. In the event the Township, pursuant to this Agreement, performs work of any nature, or expends any funds in performance of said work for labor, use of equipment, supplies, materials, and the like, the Landowner shall reimburse the Township for all expenses (direct and indirect) incurred within 10 days of receipt of invoice from the Township.

- 6. The intent and purpose of this Agreement is to ensure the proper maintenance of the onsite BMP(s) by the Landowner; provided, however, that this Agreement shall not be deemed to create or effect any additional liability of any party for damage alleged to result from or be caused by stormwater runoff.
- 7. The Landowner, its executors, administrators, assigns, and other successors in interests, shall release the Township's employees and designated representatives from all damages, accidents, casualties, occurrences or claims which might arise or be asserted against said employees and representatives from the construction, presence, existence, or maintenance of the BMP(s) by the Landowner or Township. In the event that a claim is asserted against the Township, its designated representatives or employees, the Township shall promptly notify the Landowner and the Landowner shall defend, at his own expense, any suit based on the claim. If any judgment or claims against the Township's employees or designated representatives shall be allowed, the Landowner shall pay all costs and expenses regarding said judgment or claim.
- 8. The Township shall inspect the BMP(s) at a minimum of once every three years to ensure their continued functioning.

This Agreement shall be recorded at the Office of the Recorder of Deeds of Berks County, Pennsylvania, and shall constitute a covenant running with the Property and/or equitable servitude, and shall be binding on the Landowner, his administrators, executors, assigns, heirs and any other successors in interests, in perpetuity.

IN WITNESS WHEREOF, the parties have caused this Agreement to be duly executed on the date first indicated hereinabove.

(Land	lowner)	
		_, INC.
By:		
,	President (Vice)	
Attes	t:	
	Secretary	
SPRII	NG TOWNSHIP	
By:		
,	Chairman (Vice)	
Attes	t:	
	Secretary	

COMMONWEALTH OF PENNSYLVANIA	
COUNTY OF BERKS	: ss. :
the County and State aforesaid, personation who acknowledged to do so, executed the foregoing	hemselves to be the President and Secretary oration, and that as such officers and being STORMWATER CONTROLS AND BEST
MANAGEMENT PRACTICES OPERATIONS the purposes therein contained by signing the such officers.	
IN WITNESS WHEREOF, I have	e hereunto set my hand and official seal.
	Notary Public
COMMONWEALTH OF PENNSYLVANIA	
COUNTY OF BERKS	: SS. :
On this day of, 20 County and State aforesaid, personall, who acknowledged then (Assistant) of the Board of Supervisors of Spri	008, before me, a Notary Public in and for the y appeared and nselves to be the Chairman and Secretary
township, and that as such officers and being a STORMWATER CONTROLS AND BEST MA AND MAINTENANCE AGREEMENT for the name of the Township by themselves as such	authorized to do so, executed the foregoing NAGEMENT PRACTICES OPERATIONS purposes therein contained by signing the
IN WITNESS WHEREOF, I have	e hereunto set my hand and official seal.
	Notary Public

<u>Section 1002. Appendix B – Stormwater Management Design Criteria.</u> (Ordinance No. 355, March 24, 2008, Section 1)

TABLE B-1 RUNOFF CURVE NUMBERS Source: NRCS (SCS) TR-55

TABLE B-2
RATIONAL RUNOFF COEFFICIENTS

TABLE B-3
MANNING ROUGHNESS COEFFICIENTS

FIGURE B-1
RECOMMENDATION CHART FOR INFILTRATION STORMWATER
MANAGEMENT BMPS IN CARBONATE AREAS

TABLE B-1
Runoff Curve Numbers (From NRCS (SCS) TR-55)

LAND USE DESCRIE	TION			SOIL G	
Open Space		A 44	В 65	C 77	D 82
Meadow / Orchard		30	58	71	7 8
Agricultural		59	71	79	83
Forest		36	60	73	79
Commercial	(85% Impervious)	89	92	94	95
Industrial	(72% Impervious)	81	88	91	93
Institutional	(50% Impervious)	71	82	88	90
Residential					
Average Lot Size	% impervious				
1/8 acre or less*	65	77	85	90	92
1/8 - 1/3 acre	34	59	74	82	87
1/3 - 1 acre	23	53	69	80	85
1 - 4 acres	12	46	66	78	82
Farmstead		59	74	82	86
Smooth Surfaces (Cond Gravel or Bare Compa	-	98	98	98	98
Water		98	98	98	98
Mining/Newly Grade (Pervious Areas Only)		77	86	91	94

^{*} Includes Multi-Family Housing unless justified lower density can be provided.

Note: Existing site conditions of bare earth or fallow ground shall be considered as meadow when choosing a CN value.

TABLE B-2 RATIONAL RUNOFF COEFFICIENTS By Hydrologic Soils Group and Overland Slope (%)

		Α			В			С			D	
Land Use	0-2%	2-6%	6%+	0-2%	2-6%	6%+	0-2%	2-6%	6%+	0-2%	2-6%	6%+
Cultivated Land	0.08a	0.13	0.16	0.11	0.15	0.21	0.14	0.19	0.26	0.18	0.23	0.31
	0.14b	0.18	0.22	0.16	0.21	0.28	0.20	0.25	0.34	0.24	0.29	0.41
Pasture	0.12	0.20	0.30	0.18	0.28	0.37	0.24	0.34	0.44	0.30	0.40	0.50
	0.15	0.25	0.37	0.23	0.34	0.45	0.30	0.42	0.52	0.37	0.50	0.62
Meadow	0.10	0.16	0.25	0.14	0.22	0.30	0.20	0.28	0.36	0.24	0.30	0.40
	0.14	0.22	0.30	0.20	0.28	0.37	0.26	0.35	0.44	0.30	0.40	0.50
Forest	0.05	0.08	0.11	0.08	0.11	0.14	0.10	0.13	0.16	0.12	0.16	0.20
	0.08	0.11	0.14	0.10	0.14	0.18	0.12	0.16	0.20	0.15	0.20	0.25
Residential	0.25	0.28	0.31	0.27	0.30	0.25	0.30	0.33	0.38	0.33	0.36	0.42
Lot Size 1/8 Acre	0.33	0.37	0.40	0.35	0.39	0.44	0.38	0.42	0.49	0.41	0.45	0.54
Lot Size 1/4 Acre	0.22	0.26	0.29	0.24	0.29	0.33	0.27	0.31	0.36	0.30	0.34	0.40
	0.30	0.34	0.37	0.33	0.37	0.42	0.36	0.40	0.47	0.38	0.42	0.52
Lot Size 1/3 Acre	0.19	0.23	0.26	0.22	0.26	0.30	0.25	0.29	0.34	0.28	0.32	0.39
	0.28	0.32	0.35	0.30	0.35	0.39	0.33	0.38	0.45	0.36	0.40	0.50
Lot Size 1/2 Acre	0.16	0.20	0.24	0.19	0.23	0.28	0.22	0.27	0.32	0.26	0.30	0.37
	0.25	0.29	0.32	0.28	0.32	0.36	0.31	0.35	0.42	0.34	0.38	0.48
Lot Size 1 Acre	0.14	0.19	0.22	0.17	0.21	0.26	0.20	0.25	0.31	0.24	0.29	0.35
	0.22	0.26	0.29	0.24	0.28	0.34	0.28	0.32	0.40	0.31	0.35	0.46
Industrial	0.67	0.68	0.68	0.68	0.68	0.69	0.68	0.69	0.69	0.69	0.69	0.70
	0.85	0.85	0.86	0.85	0.86	0.86	0.86	0.86	0.87	0.86	0.86	0.88
Commercial	0.71	0.71	0.72	0.71	0.72	0.72	0.72	0.72	0.72	0.72	0.72	0.72
	0.88	0.88	0.89	0.89	0.89	0.89	0.89	0.89	0.90	0.89	0.89	0.90
Streets	0.70	0.71	0.71	0.71	0.72	0.74	0.72	0.73	0.76	0.73	0.75	0.78
	0.76	0.77	0.79	0.80	0.82	0.84	0.84	0.85	0.89	0.89	0.91	0.95
Open Space	0.05	0.10	0.14	0.08	0.13	0.19	0.12	0.17	0.24	0.16	0.21	0.28
	0.11	0.16	0.20	0.14	0.19	0.26	0.18	0.23	0.32	0.22	0.27	0.39
Parking	0.85	0.86	0.87	0.85	0.86	0.87	0.85	0.86	0.87	0.85	0.86	0.87
	0.95	0.96	0.97	0.95	0.96	0.97	0.95	0.96	0.97	0.95	0.96	0.97

Runoff coefficients for storm recurrence intervals less than 25 years.
 Runoff coefficients for storm recurrence intervals of 25 years or more.

Source: Rawls, W.L. S.L. Wong and R.H. McCuen, 1981, "Comparison of Urban Flood Frequency Procedures", Preliminary of Agriculture, Soil Conservation Service, Baltimore, MD.

TABLE B-3 Roughness Coefficients (Manning's "n") For Overland Flow (U.S. Army Corps Of Engineers, HEC-1 Users Manual)

Surface Description		n	
		-	
Dense Growth	0.4	-	0.5
Pasture	0.3	-	0.4
Lawns	0.2	-	0.3
Bluegrass Sod	0.2	-	0.5
Short Grass Prairie	0.1	-	0.2
Sparse Vegetation	0.05	-	0.13
Bare Clay-Loam Soil (eroded)	0.01	-	0.03
Concrete/Asphalt - very shallow depths			
(less than 1/4 inch)	0.10	-	0.15
- small depths			
(1/4 inch to several inches)	0.05	-	0.10

Roughness Coefficients (Manning's "n") For Channel Flow

Reach Description	n
	
Natural stream, clean, straight, no rifts or pools	0.03
Natural stream, clean, winding, some pools or shoals	0.04
Natural stream, winding, pools, shoals, stony with some weeds	0.05
Natural stream, sluggish deep pools and weeds	0.07
Natural stream or swale, very weedy or with timber underbrush	0.10
Concrete pipe, culvert or channel	0.012
Corrugated metal pipe	$0.012 - 0.027^{(1)}$
High Density Polyethylene (HDPE) Pipe	
Corrugated	$0.021 - 0.029^{(2)}$
Smooth Lined	$0.012 - 0.020^{(2)}$

- (1) Depending upon type, coating and diameter(2) Values recommended by the American Concrete Pipe Association, check Manufacturer's recommended value.

FIGURE B-1 Recommendation Chart for Infiltration Stormwater Management BMPs in Carbonate Bedrock

rors	Gaalogy Type		CARBONATE BEDROCK																										
eite risk factors	Effective Soil Thickness					ot							Over 4 Feet to 8 Feet					Over 8 Foot											
erte	Special Geologic Fastures*	LowMed#igh Buffer	,	Low Buff	*	160	Medium Buffer Hi		High Bull or			Low Buffer		Medium Buffer		High Buffer		i,ow Buffer		Medium Buffor			F	To-					
	NVESTIGATION ECOMMENDED	(Unacceptable)	P	relimina 	ry	F	relimina	γ	P	relimbu	ימי	£	're limina	γ	P	retimina	y .	P	re Ernina	'n	P	rešmina	iry —	F	relimin.	ŧγ	F	relimin	ary
DESIGN FACTORS	inistration Loading Rates (% Incease) **	(Unacceptable)	0-100W	100. 300%	300 ·	0-100%	100- 300%	300 - 800%	0- 100%	100- 200%	2007L	D-100%	100- 200%	300 - 500%		100-	350 - 600%	D- 100%	100. 300%	300 · 600%	0-10 <i>0</i> %	196- 306%	300 - 500%	0-100%	100- 300%		0-100%	100- 200%	
	Gram Summary Durdance =-								,	,																			
RECOMMENDED NOT RECOMMENDED																													

* Special Geologic Feature Buffer widths are as follows:

Low Buffer is less than 50 feet Medium Buffer is 50 feet to 100 feet High Buffer is greater than 100 feet

- Rates greater than 500% not recommended.
- " Assumes adequately permeable soils and lack of natural constraints as required for all inflitration systems.
- 1 Infittration systems may be allowed at the determination of the Engineer and/or Geologist, provided that a Detailed Site investigation is undertaken which confirms nature of rock, location of Special Geologic Features, and adequacy of the buffer between the SGF and the proposed stomwater system(s).
- 2 In these Special Geologic Features: Low Buffer situations, infiltration systems may be allowed at the determination of the Engineer and/or Geologist, provided that a Detailed Site investigation is undertaken and a 25 foot buffer from SGFs is maintained.

Source: Little Lehigh Creek Watershed ACT 167 - Stormwater Management Ordinance. May 2004

Section 1003.	Appendix C - Drainage Plan Application.	(Ordinance No. 355, March
24, 2008, Section 1)		`

(To be attached to the "land subdivision plan or development plan review application or "minor land subdivision plan review application")

Application is hereby made for review of the Stormwater Management and Erosion and Sedimentation Pollution Control Plan and related data as submitted herewith in accordance with the Spring Township Stormwater Management Ordinance.

	Final Plan	Preliminary Plan	Sketch Plan	
Dat	e of Submission	Submis	ssion No	
1.	Name of subdivision or	development		
2.	Name of Applicant		Telephone No	
	if corporation, list the orporation)	corporation's name an	d the names of two officer	rs of the
_	<u>,</u> ,			Officer 1 Officer 2
A Z	Address Zip			
	Applicants interest in sulif other than property or			
3.	Name of property owne	r	Telephone No	
A Z	Address			
4.	Name of engineer or sur	veyor	Telephone No	
A Z	Address			

Э.	Ту	rpe of subdivision or development proposed:
		Single-Family Lots Townhouses Commercial (Multi-Lot) Two Family Lots Garden Apartments Commercial (One-Lot) Multi-Family Lots Mobile-Home Park Industrial (Multi-Lot) Cluster Type Lots Campground Industrial (One-Lot) Planned Residential Other () Development
6.	Li	neal feet of new road proposedL.F.
7.	Ar	rea of proposed and existing impervious area on entire tract.
	a. b.	Existing (to remain)S.F% of Property ProposedS.F% of Property
8.	Sto	ormwater
	a.	Does the peak rate of runoff from proposed conditions exceed that flow which occurred for existing conditions for the designated design storm?
	b.	Design storm utilized (on-site conveyance systems) (24 hr.) No. of Subarea Watershed Name
		Explain:
	c.	Does the submission and/or district meet the release rate criteria for the applicable subarea?
	d.	Number of subarea(s) from Chapter Appendix D of the applicable Watershed Stormwater Management Plan.
	e.	Type of proposed runoff control
	f.	Does the proposed stormwater control criteria meet the requirement/guidelines of the Stormwater Ordinance?
		If not, what variances/waivers are requested?

		Reasons		
	f.	Does the plan meet the requirements of Part 3 of the Stormwater Ordinance?		
		If not, what variances/waivers are requested?		
		Reasons Why		
	g.	Was TR-55, June 1986 utilized in determining the time of concentration?		
	h.	What hydrologic method was used in the stormwater computations?		
	i.	Is a hydraulic routing through the stormwater control structure submitted?		
	j.	Is a construction schedule or staging attached?		
	k.	Is a recommended maintenance program attached?		
9.	Erosion and Sediment Pollution Control (E&SPC):			
	a.	Has the stormwater management and E&SPC plan, supporting documentation and narrative been submitted to the Berks County Conservation District?		
	b.	Total area of earth disturbanceS.F.		
10.	W	Wetlands		
	a.	Have the wetlands been delineated by someone trained in wetland delineation?_		
	b.	Have the wetland lines been verified by a state or federal permitting authority?		
	c.	Have the wetland lines been surveyed?		
		Total acreage of wetland within the property		
	e.	Total acreage of wetland disturbed		
	f.	Supporting documentation		


11.	Filing		
	a.	Has the required fee been submitted?	
		Amount	
	b.	Has the proposed schedule of construction inspection to be performed by the Applicant's engineer been submitted?	
			
	c.	Name of individual who will be making the inspections	
	d.	General comments about stormwater management at the development	


CERTIFICATE OF OWNERSHIP AND ACKNOWLEDGMENT OF APPLICATION:


COMMONWEALTH OF PENNSYLVANIA COUNTY OF [County Name] .	
On this the day of, 20, before me, the personally appeared who being duly swedeposes and says that owners of the particular this application and that the application knowledge and/or direction and does hereby agree with the said submission of the same.	orn, according to law, property described in was made with
	Property Owner
My Commission ExpiresNotary Public	20
THE UNDERSIGNED HEREBY CERTIFIES THAT TO THE BEST C AND BELIEF THE INFORMATION AND STATEMENTS GIVEN AND CORRECT.	
SIGNATURE OF APPLICANT	
: 	
(Information Below This Line To Be Completed By The	Township)
Spring Township official submission receipt:	
Date complete application receivedPlan Number	er
Fees date fees paid received by_	
Official submission receipt date	
Received by	
Spring Township	


<u>Section 1004. Appendix D – Stormwater Management District Watershed Map(s).</u> (Ordinance No. 355, March 24, 2008, Section 1)

INTENTIONALLY LEFT BLANK









Section 1005. Appendix E – Low Impact Development (LID) Practices. (Ordinance No. 355, March 24, 2008, Section 1)

ALTERNATIVE APPROACH FOR MANAGING STORMWATER RUNOFF

Natural hydrologic conditions may be altered radically by poorly planned development practices, such as introducing unneeded impervious surfaces, destroying existing drainage swales, constructing unnecessary storm sewers, and changing local topography. A traditional drainage approach of development has been to remove runoff from a site as quickly as possible and capture it in a detention basin. This approach leads ultimately to the degradation of water quality as well as expenditure of additional resources for detaining and managing concentrated runoff at some downstream location.

The recommended alternative approach is to promote practices that will minimize proposed conditions runoff rates and volumes, which will minimize needs for artificial conveyance and storage facilities. To simulate pre-development hydrologic conditions, infiltration is often necessary to offset the loss of infiltration by creation of impervious surfaces. The ability of the ground to infiltrate depends upon the soil types and its conditions.

Preserving natural hydrologic conditions requires careful alternative site design considerations. Site design practices include preserving natural drainage features, minimizing impervious surface area, reducing the hydraulic connectivity of impervious surfaces, and protecting natural depression storage. A well-designed site will contain a mix of all those features. The following describes various techniques to achieve the alternative approach:

- Preserving Natural Drainage Features. Protecting natural drainage features, particularly vegetated drainage swales and channels, is desirable because of their ability to infiltrate and attenuate flows and to filter pollutants. However, this objective is often not accomplished in land development. In fact, commonly held drainage philosophy encourages just the opposite pattern streets and adjacent storm sewers typically are located in the natural headwater valleys and swales, thereby replacing natural drainage functions with a completely impervious system. As a result, runoff and pollutants generated from impervious surfaces flow directly into storm sewers with no opportunity for attenuation, infiltration, or filtration. Developments designed to fit site topography also minimizes the amount of grading on site.
- Protecting Natural Depression Storage Areas. Depressional storage areas have no surface outlet, or drain very slowly following a storm event. They can be commonly

seen as ponded areas in farm fields during the wet season or after large runoff events. Traditional development practices eliminate these depressions by filling or draining, thereby obliterating their ability to reduce surface runoff volumes and trap pollutants. The volume and release-rate characteristics of depressions should be protected in the design of the development site. The depressions can be protected by simply avoiding the depression or by incorporating its storage as additional capacity in required detention facilities.

- Avoiding introduction of impervious areas. Careful site planning should consider reducing impervious coverage to the maximum extent possible. Building footprints, sidewalks, driveways and other features producing impervious surfaces should be evaluated to minimize impacts on runoff.
- Reducing the Hydraulic Connectivity of Impervious Surfaces. Impervious surfaces are significantly less of a problem if they are not directly connected to an impervious conveyance system (such as storm sewer). Two basic ways to reduce hydraulic connectivity are routing of roof runoff over lawns and reducing the use of storm sewers. Site grading should promote increasing travel time of stormwater runoff, and should help reduce concentration of runoff to a single point in the development.
- Routing Roof Runoff Over Lawns. Roof runoff can be easily routed over lawns in
 most site designs. The practice discourages direct connections of downspouts to
 storm sewers or parking lots. The practice also discourages sloping driveways and
 parking lots to the street. By routing roof drains and crowning the driveway to run
 off to the lawn, the lawn is essentially used as a filter strip.
- Using Permeable Paving Materials. These materials include permeable interlocking concrete paving blocks or porous bituminous concrete. Such materials should be considered as alternatives to conventional pavement surfaces in privately owned and maintained areas, especially for low use surfaces such as driveways, overflow parking lots, and emergency access roads.

The following describes additional techniques that may be acceptable under certain conditions to achieve the alternative approach. Their use is dependent upon additional factors such as Zoning and Subdivision and Land Development regulations and these techniques are to be employed only upon approval of the appropriate Township entity:

 Reducing the Use of Storm Sewers. By reducing use of storm sewers for draining streets, parking lots, and back yards, the potential for accelerating runoff from the development can be greatly reduced. The practice requires greater use of swales and may not be practical for some development sites, especially if there are concerns for areas that do not drain in a "reasonable" time. The practice requires educating local citizens and public works officials, who expect runoff to disappear shortly after a rainfall event.

- Reducing Street Widths. Street widths can be reduced by either eliminating onstreet parking or by reducing roadway widths. Township planners and traffic designers may give consideration to narrower neighborhood streets which ultimately could lower maintenance.
- Limiting Sidewalks to One Side of the Street. A sidewalk on one side of the street may suffice in low-traffic neighborhoods. The lost sidewalk could be replaced with bicycle/recreational trails that follow back-of-lot lines. Where appropriate, backyard trails should be constructed using pervious materials.
- Constructing Open Space Developments. Open Space developments can also reduce the amount of impervious area for a given number of lots. The biggest savings is in street length, which also will reduce costs of the development. Open Space development clusters the construction activity onto less-sensitive areas without substantially affecting the gross density of development.

In summary, a careful consideration of the existing topography and implementation of a combination of the above mentioned techniques may avoid construction of costly stormwater control measures. Other benefits include reduced potential of downstream flooding, water quality degradation of receiving streams/water bodies and enhancement of aesthetics and reduction of development costs. Beneficial results include more stable baseflows in receiving streams, improved groundwater recharge, reduced flood flows, reduced pollutant loads, and reduced costs for conveyance and storage.

Section 1006. Appendix F – West Nile Virus Guide. (Ordinance No. 355, March 24, 2008, Section 1)

(This source is from the Monroe County, PA Conservation District who researched the potential of West Nile Virus problems from BMPs due to a number of calls they were receiving)

Monroe County Conservation District Guidance:
Stormwater Management and West Nile Virus
Source: Brodhead McMichaels Creeks Watershed Act 167 Stormwater Management
Ordinance 2/23/04

The Monroe County Conservation District recognizes the need to address the problem of non-point source pollution impacts caused by runoff from impervious surfaces. The new stormwater policy being integrated into Act 167 Stormwater Management regulations by the PA Department of Environmental Protection (PaDEP) will make non-point pollution controls an important component of all future plans and updates to existing plans. In addition, to meet post-construction anti-degradation standards under the state National Pollution Discharge Elimination System (NPDES) permitting program, applicants will be required to employ Best Management Practices (BMPs) to address non-point pollution concerns.

Studies conducted throughout the United States have shown that wet basins and in particular constructed wetlands are effective in traditional stormwater management areas such as channel stability and flood control, and are one of the most effective ways to remove stormwater pollutants (United States Environmental Protection Agency 1991, Center for Watershed Protection 2000). From Maryland to Oregon, studies have shown that as urbanization and impervious surface increase in a watershed, the streams in those watersheds become degraded (CWP 2000). Although there is debate over the threshold of impervious cover when degradation becomes apparent (some studies show as little as 6% while others show closer to 20%), there is agreement that impervious surfaces cause non-point pollution in urban and urbanizing watersheds, and that degradation is ensured if stormwater BMPs are not implemented.

Although constructed wetlands and ponds are desirable from a water quality perspective there may be concerns about the possibility of these stormwater management structures becoming breeding grounds for mosquitoes. The Conservation District feels that although it may be a valid concern, municipalities should not adopt ordinance provisions prohibiting wet basins for stormwater management.

Mosquitoes

The questions surrounding mosquito production in wetlands and ponds have intensified in recent years by the outbreak of the mosquito-borne West Nile Virus. As is the case with all vector-borne maladies, the life cycle of West Nile Virus is complicated, traveling from mosquito to bird, back to mosquito and then to other animals including

humans. *Culex pipiens* was identified as the vector species in the first documented cases from New York in 1999. This species is still considered the primary transmitter of the disease across its range. Today there are some 60 species of mosquitoes that inhabit Pennsylvania. Along with *C. pipiens*, three other species have been identified as vectors of West Nile Virus while four more have been identified as potential vectors.

The four known vectors in NE Pennsylvania are *Culex pipiens*, *C. restuans*, *C. salinarius* and *Ochlerotatus japonicus*. All four of these species prefer, and almost exclusively use, artificial containers (old tires, rain gutters, birdbaths, etc.) as larval habitats. In the case of *C. pipiens*, the most notorious of the vector mosquitoes, the dirtier the water the better they like it. The important factor is that these species do not thrive in functioning wetlands where competition for resources and predation by larger aquatic and terrestrial organisms is high.

The remaining four species, Aedes vexans, Ochlerotatus Canadensis, O. triseriatus and O. trivittatus are currently considered potential vectors due to laboratory tests (except the O. trivittatus, which did have one confirmed vector pool for West Nile Virus in PA during 2002). All four of these species prefer vernal habitats and ponded woodland areas following heavy summer rains. These species may be the greatest threat of disease transmission around stormwater basins that pond water for more than four days. This can be mitigated however by establishing ecologically functioning wetlands.

Stormwater Facilities

If a stormwater wetland or pond is constructed properly and a diverse ecological community develops, mosquitoes should not become a problem. Wet basins and wetlands constructed as stormwater management facilities, should be designed to attract a diverse wildlife community. If a wetland is planned, proper hydrologic soil conditions and the establishment of hydrophytic vegetation will promote the population of the wetland by amphibians and other mosquito predators. In natural wetlands, predatory insects and amphibians are effective at keeping mosquito populations in check during the larval stage of development while birds and bats prey on adult mosquitoes.

The design of a stormwater wetland must include the selection of hydrophytic plant species for their pollutant uptake capabilities and for not contributing to the potential for vector mosquito breeding. In particular, species of emergent vegetation with little submerged growth are preferable. By limiting the vegetation growing below the water surface, larvae lose protective cover and there is less chance of anaerobic conditions occurring in the water.

Stormwater ponds can be designed for multiple purposes. When incorporated into an open space design a pond can serve as a stormwater management facility and a community amenity. Aeration fountains and stocked fish should be added to keep larval mosquito populations in check.

Publications from the PA Department of Health and the Penn State Cooperative Extension concerning West Nile Virus identify aggressive public education about the risks posed by standing water in artificial containers (tires, trash cans, rain gutters, bird baths) as the most effective method to control vector mosquitoes.

Conclusion

The Conservation District understands the pressure faced by municipalities when dealing with multifaceted issues such as stormwater management and encourages the incorporation of water quality management techniques into stormwater designs. As Monroe County continues to grow, conservation design, groundwater recharge and constructed wetlands and ponds should be among the preferred design options to reduce the impacts of increases in impervious surfaces. When designed and constructed appropriately, the runoff mitigation benefits to the community from these design options will far out weigh their potential to become breeding grounds for mosquitoes.

<u>Section 1007.</u> Appendix G - References. (Ordinance No. 355, March 24, 2008, Section 1)

BMP Manuals

California

California Stormwater BMP Handbook: New Development and Redevelopment (January 2003) – separate file available at

http://www.cabmphandbooks.org/Development.asp

Georgia

Georgia Stormwater Management Manual Volume 2: Technical Handbook (August 2001) separate file (http://www.georgiastormwater.com/)

Maryland

2000 Maryland Stormwater Design Manual -

http://www.mde.state.md.us/Programs/Waterprograms/SedimentandStormwater/stormwater design/index.asp

Massachusetts

Stormwater Management, Volume Two: Stormwater Technical Handbook (Massachusetts, 1997) – separate file available at http://www.state.ma.us/dep/brp/stormwtr/stormpub.htm

Minnesota

Minnesota Urban Small Sites BMP Manual: Stormwater Best Management Practices for Cold Climates (July 2001) –

http://www.metrocouncil.org/environment/Watershed/BMP/manual.htm

New Jersey

Revised Manual for New Jersey: Best Management Practices for Control of Non-point Source Pollution from Stormwater (Fifth Draft May 2000) – http://www.state.nj.us/dep/watershedmgt/bmpmanual.htm

New York

New York State Stormwater Management Design Manual (2001) – http://www.dec.state.ny.us/website/dow/swmanual/swmanual.html

Pennsylvania

Pennsylvania Association of Conservation Districts, Pennsylvania Handbook of Best Management Practices for Developing Areas, November 14, 1997.

Pennsylvania Department of Environmental Protection, Pennsylvania Stormwater Best Management Practices Manual, December 30, 2006 –

http://www.depweb.state.pa.us/watershedmgmt/cwp/view.asp?a=1437&Q=518682&

PM=1

Washington

Stormwater Management Manual for Western Washington (August 2001) - http://www.ecy.wa.gov/programs/wq/stormwater/manual.html

Federal

Stormwater Best Management Practices in an Ultra-Urban Setting: Selection and Monitoring (FHWA) – http://www.fhwa.dot.gov/environment/ultraurb/3fs1.htm

USEPA Infiltration Trench Fact Sheet (September 1999) – http://cfpub.epa.gov/npdes/stormwater/menuofbmps/post.cfm

Riparian Buffer References

- Alliance for the Chesapeake Bay, Pennsylvania Department of Environmental Protection, September 2000. Forest Buffer Toolkit, Stream ReLeaf Program.
- Penn State College of Agricultural Sciences, 1996. Establishing Vegetative Buffer Strips Along Streams to Improve Water Quality. Publication # AGRS-67.
- Fike, Jean, June 1999. Terrestrial & Palustrine Plant Communities of Pennsylvania, Pennsylvania Natural Diversity Inventory, The Nature Conservancy, Western Pennsylvania Conservancy, and Pennsylvania Department of Conservation and Natural Resources.
- Pennsylvania Association of Conservation Districts, Inc., Keystone Chapter, Soil and Water Conservation Society, Pennsylvania Department of Environmental Protection, Natural Resources Conservation Service, 1998. Pennsylvania Handbook of Best Management Practices for Developing Areas. Prepared by CH2MHill.
- Palone, R. S. and A. H. Todd (eds), 1997. Chesapeake Bay Riparian Handbook: A Guide for Establishing and Maintaining Riparian Forest Buffers. Chesapeake Bay Program and Northeastern Area State and Private Forestry. Natural Resources Conservation Service Cooperative State Research Education and Extension Services.
- The Federal Interagency Stream Restoration Working Group (FISRWG, 10/1998). Stream Corridor Restoration Principles, Processes, and Practices. GPO Item No. 0120-A; SuDocs No. A57.6/2:EN3/PT.653. ISBN-0-934213-59-3. Published October 1998. Revised August 2000.